



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/ WZ/CNG/2025/512

Dated: 23/09/2025

FIRE SAFETY CERTIFICATE

Certified that the CNG Station located at Punjabi Bagh, New Delhi – 110026, comprised of ground floor only, was issued FSC by this department Vide letter no. F6/DFS/MS/WZ/2022/CNG/439 dated 30/09/2022. The Premises was re-inspected by the officer concerned of this department on 12/09/2025 in the presence of Sh. Sumit Kumar (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have deemed complied with fire prevention and fire safety requirements in accordance with rule OISD 179 & the premises is fit for occupancy class “Hazardous” (Group-J) with effect from 23/09/2025 for a period of three years in accordance with OISD/ 179/ rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on 23/09/2025 at New Delhi by.


23/09/2025
Virendra Singh
Chief Fire Officer

Copy To: -

1. Sh. Ajay Kumar Khatri (DGM-Fire and safety), IGL Bhawan, Plot No.4, Community Centre, Sector – 9, R.K. Puram, New Delhi – 110022.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. Only Fire protection facilities were checked as per OISD 179 (Para 19). The other safety requirement must be ascertained by the authority concerned.

INSPECTION REPORT

1.	Name & address of the building	CNG Station, Located at Punjabi Bagh, New Delhi-110026.		
2.	Type of Occupancy	Hazardous		
3.	Type of Case	Renewal		
4.	Details of previous NOC	F6/DFS/MS/WZ/2022/CNG/439 dated 30/09/2022		
5.	Fire Safety directives letter No	OISD-179		
6.	Date of inspection	09/09/2025		
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)		
8.	Name and designation of officers from the building side	Sh. Sumit Kumar (Manager)		
9.	Year of Construction	2000 (As per prev. Insp. Report dated 17/09/2022)		
10.	Applicant's letter No.	IGL/F&S/2025/15/89/1 dated 18/08/2025		
S. No	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	<div style="text-align: center;">6 m</div> <div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div>	<div style="text-align: center;">30m Provided</div> <div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div>	<div style="text-align: center;">MR</div> <div style="text-align: center;">MR</div> <div style="text-align: center;">NA</div>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	<div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div>	<div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div>	<div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div>
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	<div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div>	<div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div>	<div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div>
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	<div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div>	<div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div>	<div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div>
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	<div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div>	<div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div>	<div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div>
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	<div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div>	<div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div>	<div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div>
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	<div style="text-align: center;">14 nos.</div> <div style="text-align: center;">CO₂, ABC type</div> <div style="text-align: center;">ISI marked</div>	<div style="text-align: center;">29 Provided</div> <div style="text-align: center;">Provided</div> <div style="text-align: center;">Provided</div>	<div style="text-align: center;">MR</div> <div style="text-align: center;">MR</div> <div style="text-align: center;">MR</div>
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	<div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div>	<div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div>	<div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div> <div style="text-align: center;">NA</div>

7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Hand held explosive meter/detector	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	CO₂ Flooding System			
	<ul style="list-style-type: none"> Ground Floor Upper Floor Sprinkler above false ceiling 	Required in compressor area	Provided	MR
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of minimum standards of fire prevention and fire safety required under the rules, the NOC vide letter No F6/DFS/MS/WZ/2022/CNG/439 dated 30/09/2022, renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

4/ADO/MN
16/09/25

Dy CRO (WZ)

16/9

DCFO/822-WD
Date: 16/09/25

CFO / 18/9/2025
Principal Director

CFO to Secy.

18/09/25

ADO (MN)

19/9/2025

Sir, F.T is put up for your kind personal & signature please.

C.R.O / 23/9/2025

23/9/2025

MS