

5

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI-110 001.**

No. F.6/DFS/MS/CNG/2025/SZ/ 485

Dated: 15/09/25

**FIRE SAFETY CERTIFICATE**

Certified that the Hybrid CNG Station at Khasra No. 5/23/1, Village- Kharkhari Nahar, Tehsil Najafgarh, Delhi-110043, comprised of ground floor only, (03 Dispenser with 06 points) owned/occupied by M/s Indraprastha Gas Limited, was issued FSC by this department vide letter No. F.6/DFS/MS/CNG/2022/SZ/432 dated 28.09.2022. The premises was re-inspected by the officer concerned of this department on dated 01.09.2025 in the presence of Sh. Vikram Yadav (Manager) and found that Hybrid CNG station have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises (Hybrid CNG Station) is fit for occupancy class Group "J" "Hazardous Building" w.e.f. 15/09/25 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 15/09/25 at New Delhi.

15/09/25  
(Virendra Singh)  
Chief Fire Officer  
07/09/25

Copy to:-

1. The Vice-President (F&S), Indraprastha Gas Limited, IGL Bhawan, Plot No.-4, Community Centre, Sector-9, R.K.Puram, New Delhi-110022.
2. The Manager, Hybrid CNG Station at Khasra No. 5/23/1, Village- Kharkhari Nahar, Tehsil Najafgarh, Delhi-110043

**Conditions for the validity of fire safety certificate: -**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

# INSPECTION REPORT

- | CHECKING REPORT   |   |
|---|---|
| 1. Name & address of the building                             | : CNG Station at khasra No. 5/23/1, Village- Kharkhari Nahar, Tehsil Najafgarh, Delhi-110043. |
| 2. Type of Occupancy  | : Group "J" Hazardous (CNG Facility)  |
| 3. Building comprised of                                      | : Ground floor only.  |
| 4. Type of Case   | : Renewal   |
| 5. Details of Previous NOC                                    | : F.6/DFS/MS/CNG/2022/SZ/432 dated 28.09.2022   |
| 6. Fire Safety directives letter No                           | : Nil   |
| 7. Date of inspection   | : 01.09.2025  |
| 8. Name of Inspecting Officer                                 | : ADO R.K.Yadav   |
| 9. Name and designation of officers<br>From the building side | : Sh. Vikram Yadav (Manager)  |
| 10. Year of Construction                                      | : 2020-21   |
| 11. Applicant's letter No.                                    | : IGL/F&S/2025/15/115/1 dated 18.08.2025  |

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	NFPA/CCOE/OISD etc. requirements	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	12 m NA NA	45 m Provided Directly accessible from road NA	MR NA NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	NA	NA	NA
	b. Width of staircases	NA	NA	NA
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basements</li> </ul>	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	NA	NA	NA
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	12 Nos. Required ISI	Provided 6 Nos. DCP Type (3 kg), 4 Nos. CO2 Type 4.5 kg, 2 Nos. DCP Type (75 kg) trolly mounted Provided	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	NA NA NA	NA NA NA	NA NA NA



7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Gas and flame detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Required	Provided	MR
		Required	Office at GF	NA
		NA	NA	NA
		Required	Provided	MR
		Required	At station	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/Manual Stopping</li> </ul> </li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>			
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15.	No Smoking Signage.	Required	Provided in Hindi & English	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

17.	Standby power supply	NA	Provided (DG Set)	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	CO <sub>2</sub> flooding system in compressor	Provided	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/CNG/2022/SZ/432 dated 28.09.2022, **is recommended to be renewed** under rule 37, of the Delhi Fire Service Rules, 2010.

**Note:** - Sand buckets are provided in the premises & No smoking boards adequately displayed in English and Hindi. Advance fire water mist cum foam trolley is provided. Two hand held explosive meters are also provided.

*R.K. Yadav*  
02/9/2025  
Signature of Inspecting Officer  
Name: - R.K. Yadav  
Designation: - ADO (JKP)

DO (SW)

*R.K.*  
3/9/25

*CFO*

*Mup*  
6/9/2025

Principal Director

*CFO to Secy*

*Q*  
09/09/25

*CFO*

*Mup*  
10/9/2025

ADO (JKP)