



No. F6/DFS/MS/CNG/NDZ/2025/ 66

Dated: 10/02/2025

FIRE SAFETY CERTIFICATE

Certified that the CNG Station at IFC-5, Pocket-A, Ghazipur, Ghazipur Sabji Mandi Road, Delhi-96, Comprised of ground floor only, owned/occupied by Indraprastha Gas Limited was granted FSC by this department vide letter no. F6/DFS/MS/CNG/2022/62 dated 10/02/2022. The premises was re-inspected by the officer concerned of this department on 30/01/2025 in the presence of Mr. Mayank Mishra (GET-F&S) and found that the CNG station have deemed complied with the fire prevention and fire safety requirements in accordance with the earlier directive issued vide letter no. F6/DFS/MS/CNG/2019/817 dated 08/02/2019 and found that the premises is fit for occupancy class **Hazardous Group J** with effect from 10/02/2025 for period of **three years** in accordance with Rule 36 unless under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 printed bellow.

Issued on 10/02/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

01/02/2025
DELHI FIRE SERVICE

Copy to: -

1. The General Manager, M/s Indraprastha Gas Ltd. IGL Bhawan, Plot No. 04, Community Center, R.K. Puram Sector - 09, New Delhi - 110022.

Conditions for the validity of Fire Safety Certificate

1. No trade susceptible to cause to CNG by generating head, mechanical/ electrical spark should be allowed within the licensed premises.
2. Overhead electrical cable and loose/naked wiring shall not be allowed across the licensed premises. The electrical equipment, electrical gadgets and fitting in the premises shall conform to hazardous area classification for the at purpose and be of a type approved by the CCE.
3. In premises "NO Smoking" signs board both Hindi and English shall be displayed in such a manner as to be easily readable by all people.
4. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. Noting contravention of the explosive Act. 1884 and rules their under 1983, and static mobile pressure vessels (Unfired) Rules 1981 as modified from time to time.
7. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. May be got verified from the concerned authorities..
8. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction/ unauthorized use of land if any.
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [Sub rule(1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

INSPECTION REPORT


1	Name & address of the building	CNG Station at IFC-5, Pocket-A Ghazipur, Ghazipur Sabji Mandi Road Delhi-96		
2	Building is comprised of	Ground floor.		
3	Type of occupancy	Hazardous Group J		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/CNG/2022/62 dated 10/02/2022		
6	Fire safety directives letter no.	F6/DFS/MS/CNG/2019/817 dated 08/02/2019		
7	Date of inspection	30/01/2025		
8	Name of the inspecting officers	Yashwant Singh Meena ADO/Laxmi Nagar)		
9	Name of the designation of officer from the building side	Mr. Mayank Mishra (GET-F&S)		
10	Year of construction	2018		
11	Applicant's letter no.	Outdoor dairy no. 1603 dated 13/05/2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	As per Directives	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	12 meters.	30 meters.	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases	N/A	N/A	N/A
	B Width of staircases	N/A	N/A	N/A
3	Compartmentation:			
		N/A	N/A	N/A
4	Smoke Management System:			
		N/A	N/A	N/A
5.	Fire Extinguisher:			
	A DCP Type 9 kg	10 nos.	10 nos.	MR
	B DCP Type 75 kg	06 nos.	06 nos.	MR
	C ISI marking	ISI Marked	ISI Marked	MR
6	First-Aid-Hose Reel:			
	A Total numbers of each floor	N/A	N/A	N/A
	B Length of hose reel hose	N/A	N/A	N/A
	C Nozzle diameter	N/A	N/A	N/A
7	Automatic Fire Detection and Alarming System:			
	A Type of detectors	Gas	Provided	MR
	B Location of main panel	At. Gr. floor	Provided	MR
	C Alternate source of power	Required	Provided	MR
	D Hooters	At. Gr. floor	Provided	MR
8	MOEFA:			
		Required	Provided	MR
9	Public Address System:			
		N/A	N/A	N/A
10	Automatic Sprinkler System:			
		N/A	N/A	N/A
11	Internal Hydrants:			
		N/A	N/A	N/A
12	Yard Hydrants:			
		N/A	N/A	N/A
13	Pumping Arrangements:			
	A Terrace Level	N/A	N/A	N/A
	B Discharge of pump	N/A	N/A	N/A
	C Head of the pump	N/A	N/A	N/A
	D Power supply	N/A	N/A	N/A
	E Auto starting of pump	N/A	N/A	N/A

N-08

14	Captive Water Storage for Fire Fighting			
15	Exit Signage/ No Smoking Signage	Required	provided	MR
16	Provision of Lifts	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
20	Special Fire Protection systems			
	A CO2, flooding system 45 kg	Required	Provided	MR
	B Water mist trolley	Required	Provided	MR
	C Miniature Circuit Breaker	Required	Provided	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of above deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC / FSC was issued vide letter no. F6/DFS/MS/CNG/2022/62 dated 10/02/2022 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.
No file is pending with me before disposal of this case.


30/1/2025
Signature of the Inspecting Officer
Name Yashwant Singh Meena
Designation ADO (Laxmi Nagar)

D.O/ED

AK prasad
04/02/2025

By: C.F.O/(NBZ) - On leave.

C.F.O Hugh
4/2/2025

Director 4/2/25

May LW

Sir.

F.T letter is setup for sign. Please

Director 4/2/25


7/2/2025