

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/CNG/2025/WZ/158

Dated:- 02/04/2025

FIRE SAFETY CERTIFICATE

Certified that the CNG Station at Khasra No. 78/12/2/78/18, Village Ghevra, Tehsil Kanjhawala, Delhi-110043 Comprised of Ground Floor only (04 Nos. dispenser, 02 Nos. Compressor & 02 Nos. Cascade at Ground floor) owned/occupied by M/s. Indraprastha Gas Limited, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/CNG/2022/WZ/129 Dated 25/03/2022. The said premise was re-inspected by the officer concerned of this department on 28/03/2025 in the presence of Sh. Rohit Mahajan, (Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class **"Hazardous Building" Group - J** with effect from 02/04/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 02/04/2025 at New Delhi by

(Atul Garg)
Director
Tel. No. 011-23414000

Copy to:-

1. The Chief Manager (CNG PROJECTS), IGL Bawan, Plot no. 4, Community Centre, Sector-9, R.K. Puram, New Delhi-110022.

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of authorized construction or alteration (Clause of 1.4.3 of UBBL-2016), if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	CNG Station at Khasra No. 78/12/2/78/18, Village Ghevra, Tehsil Kanjhawala, Delhi-110043
2	Type of Occupancy	Hazardous "Group- J"
3	Type of Case	Renewal (comprised of ground floor only & having 02 nos Compressor, 02 nos. cascade & 04 nos. Dispenser)
4	Details of Previous NOC	Nil
5	Fire Safety Directives Letter No	F6/DFS/MS/CNG/2022/WZ/129 dated 25/03./2022
6	Date of Inspection	28/03/2025
7	Name of the Inspecting Officers	Aman Kumar Lathar, ADO (JWP)
8	Name & Designation of Officers from the building side	Sh. Rohit Mahahjan (Manager)
9	Year of construction	2020-21
10	Applicant letter No.	IGL/F&S/2025/15/158/1 dated 18/03/2025

S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	NFPA/CCOE/OISD etc. requirements	Provided at Site	Remarks NR/NMR
-------	---	----------------------------------	------------------	----------------

1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	10.5 m -N/A- -N/A-	Provided Direct accessible from road -N/A-	MR -N/A- -N/A-

2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	<ul style="list-style-type: none"> Upper floors. Basement floor. 	-N/A- -N/A-	-N/A- -N/A-	-N/A- -N/A-
	b) Width of Staircase			
	<ul style="list-style-type: none"> Upper floors Basement floor 	-N/A- -N/A-	-N/A- -N/A-	-N/A- -N/A-
	c) Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	-N/A- -N/A-	-N/A- -N/A-	-N/A- -N/A-
	d) No. of continuous staircase to terrace	-N/A-	-N/A-	-N/A-
	e) Width of corridor	-N/A-	-N/A-	-N/A-
	f) Door size	-N/A-	-N/A-	-N/A-

3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door. Sealing of electrical shafts. Fire rating of shaft door. Water curtain Fire dampers. 	-N/A- -N/A- -N/A- -N/A- -N/A-	-N/A- -N/A- -N/A- -N/A- -N/A-	-N/A- -N/A- -N/A- -N/A- -N/A-

4.	Smoke Management system.			
	<ul style="list-style-type: none"> Basement Upper floors 	-N/A- -N/A-	-N/A- -N/A-	-N/A- -N/A-

5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types ISI Marking 	Required DCP & CO ₂ ISI marked	Provided DCP 9kg - 04, wheel mounted 75 kg-01, CO ₂ 4.5 kg -02, water mist cum foam trolley-01 Provided	MR MR MR

6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose-reel hose. 	-N/A- -N/A-	-N/A- -N/A-	-N/A- -N/A-

	• Nozzle Diameter	-N/A-	-N/A-	
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Gas and flame detectors in compressor packages area Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Required	Provided	
		Required	At GF	MR
		-N/A-	-N/A-	-N/A-
		Required	Provided	MR
		Required	At Station	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	-N/A-	-N/A-	-N/A-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement. Upper floors Sprinkler above false ceiling 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer Number of Hydrant per floor Hose box. 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
13.	Pumping arrangements.			
	• Ground Level			
	Discharge of main pump.	-N/A-	-N/A-	-N/A-
	➤ Head of main pump.	-N/A-	-N/A-	-N/A-
	➤ Number of main pumps.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump output.	-N/A-	-N/A-	-N/A-
	➤ Jockey Pump head.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump output.	-N/A-	-N/A-	-N/A-
	➤ Standby Pump head.	-N/A-	-N/A-	-N/A-
	➤ Auto Starting/Manual stopping.	-N/A-	-N/A-	-N/A-
	➤ Pump house access.	-N/A-	-N/A-	-N/A-
	• Terrace Level			
	➤ Discharge of pump.	-N/A-	-N/A-	-N/A-
	➤ Head of pump.	-N/A-	-N/A-	-N/A-
	➤ Power supply.	-N/A-	-N/A-	-N/A-
	➤ Auto starting of pump.	-N/A-	-N/A-	-N/A-
14.	Captive water storage for firefighting.			
	<ul style="list-style-type: none"> Underground tank capacity. ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. Overhead tank capacity. 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
15.	No Smoking Signage/Flammable Gas signage	Required	Provided in Hindi & English	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. 	-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-
		-N/A-	-N/A-	-N/A-

	• Lift signage.	-N/A-	-N/A-	-N/A-
17	Standby Power Supply	-N/A-	Provided (DG Set)	-N/A-
18.	Refuge Area			
	• Total area	-N/A-	-N/A-	-N/A-
	• Location	-N/A-	-N/A-	-N/A-
19.	Fire Control Room.			
	• Detector System Panel.	-N/A-	-N/A-	-N/A-
	• Flow Switch Panel.	-N/A-	-N/A-	-N/A-
	• PA system Panel.	N/A-	N/A-	N/A-
	• Battery backup	-N/A-	-N/A-	-N/A-
	• Building floor plan	-N/A-	-N/A-	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Fire Buckets filled with sand, electrical wiring, in metal conduit, CO ₂ flooding system in compressor package		MR

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In View of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, renewal of FSC issued vide letter no. F6/DFS/MS/CNG/2022/WZ/129 dated 25/03/2022 is recommended under the rule 37 of the Delhi Fire Service rule, 2010 under the DFS Act 2009.

Note:

1. Advance fire water mist com foam trolley is provided and found functional.
2. Two hand held explosive meter in working conditions.

Accordingly DFA is put up for approval and signature please.

Aman Kumar Lathar
ADO (JWP)

DCFO/1188-NW...

Dated.. 01/04/25...

CF/ Singh
01/04/2025

Director/ H/ 21/4/25

Director/ H/

See, R.F. letter is added for signature of
01/04/25