



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

4FA+FT
7/5
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/CNG/NDZ/2025/ 383

Dated: 14/07/2025

FIRE SAFETY CERTIFICATE

Certified that the CNG Station at, IFC-4, Pocket-A, Gazipur, NH-24, Delhi-110096, Comprised of ground plus one upper floor only, owned/occupied by **Indraprastha Gas Limited** was granted FSC by this department vide letter no. F6/DFS/MS/CNG//2022/324 dated 22/07/2022. The premises was re-inspected by the officer concerned of this department on 05/07/2025 in the presence of Mr. Prashant Saini (Manager) and found that the CNG station have deemed complied with the fire prevention and fire safety requirements in accordance with the earlier directive issued vide letter no. F.6/DFS/MS/CNG/2019//793 dated 08/02/2019 and found that the premises is fit for occupancy class **Hazardous Group J** with effect from 14/07/2025 for period of **three years** in accordance with Rule 36 unless under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 printed bellow.

Issued on 14/07/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE
WA 50

Copy to: -

1. The General Manager, M/s Indraprastha Gas Ltd. IGL Bhawan, Plot No. 04, Community Center, R.K. Puram Sector - 09, New Delhi - 110022.

Conditions for the validity of Fire Safety Certificate

1. No trade susceptible to cause to CNG by generating head, mechanical/ electrical spark should be allowed within the licensed premises.
2. Overhead electrical cable and loose/naked wiring shall not be allowed across the licensed premises. The electrical equipment, electrical gadgets and fitting in the premises shall conform to hazardous area classification for the purpose and be of a type approved by the CCE.
3. In premises "NO Smoking" signs board both Hindi and English shall be displayed in such a manner as to be easily readable by all people.
4. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. Noting contravention of the explosive Act. 1884 and rules their under 1983, and static mobile pressure vessels (Unfired) Rules 1981 as modified from time to time.
7. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. May be got verified from the concerned authorities.
8. This Fire Safety Certificate may not be treated in any case for regularizations, of unauthorized construction/ unauthorized use of land if any.
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [Sub rule(1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	CNG Station at, IFC-4, Pocket-A, Gazipur, NH-24, Delhi-110096.		
2	Building is comprised of	Ground floor		
3	Type of occupancy	Hazardous Group - J		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/CNG//2022/324 dated 22/07/2022		
6	Fire safety directives letter no.	F.6/DFS/MS/CNG/2019//793 dated 08/02/2019		
67	Date of inspection	05.07.2025		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mr. Prashant Saini (Manager)		
10	Year of construction	2018		
11	Applicant's letter no.	Outdoor dairy no. 3310 dated 02/07/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			MR
	A Road width	30 meters.	30 meters.	N/A
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			N/A
	a Upper floor	N/A	N/A	N/A
	b Basement	N/A	N/A	N/A
	B Width of staircases			N/A
	a Upper floor	N/A	N/A	N/A
	b Basement	N/A	N/A	N/A
	C Protection of exits			N/A
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	N/A	N/A	N/A
	E Width of corridor	N/A	N/A	N/A
	F Door size	N/A	N/A	N/A
3	Compartmentation:			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	Required	Provided	MR

②

5. Fire Extinguisher:					
	A	Total numbers	22 nos.	22 nos.	MR
	B	Types	DCP Type 09 kg(10 nos), DCP Type 75 kg(06 nos), 4.5 kg Co ₂ -04 nos, water mist trolley-01 no & 45 kg Co ₂ -01 no	DCP Type 09 kg(10 nos), DCP Type 75 kg(06 nos), 4.5 kg Co ₂ -04 nos, water mist trolley-01 no & 45 kg Co ₂ -01 no	MR
	C	ISI marking	Required	Provided	MR
6 First-Aid-Hose Reel:					
	A	Total numbers of each floor	N/A	N/A	N/A
	B	Length of hose reel hose	N/A	N/A	N/A
	C	Nozzle diameter	N/A	N/A	N/A
7 Automatic Fire Detection and Alarming System:					
	A	Type of detectors	Gas/flame	Provided	MR
	B	Location of main panel	At. Gr. floor	Provided	MR
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	Required	Provided	MR
	E	Hooters	At. Gr. floor	Provided	MR
8	MOEFA:		Required	Provided	MR
9	Public Address System:		N/A	N/A	N/A
10 Automatic Sprinkler System:					
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:					
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12 Yard Hydrants:					
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13 Pumping Arrangements:					
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	N/A	N/A	N/A
	B	Head of the pump	N/A	N/A	N/A
	C	Power supply	N/A	N/A	N/A
	D	Auto starting of pump	N/A	N/A	N/A

N/8

CNG Station at, IFC-4, Pocket-A, Gazipur, NH-24, Delhi-110096.

14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	N/A	N/A
	B	Draw-off connection	N/A	N/A
	C	Fire service inlet	N/A	N/A
	D	Access to tank	N/A	N/A
	E	Overhead tank capacity	N/A	N/A
15	Exit Signage:		Required	Provided
16	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	N/A	N/A
17	Standby Power Supply:		Required	Provided
18	Refuge Area:			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19	Fire Control Room:			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:			Provided
	1. Co ₂ flooding system in compressor packages area.			MR
	2. DCP flooding system in CNG caseades.			
	3. Miniature Circuit Breakers			

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of the FSC issued vide letter no. F6/DFS/MS/CNG//2022/324 dated 22/07/2022, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended to be renewed.

No file is pending with me before disposal of this case.

Signature Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO (Laxmi Nagar)

DO/ED 9.7.2025
 By C.F.O. (222)
 C.F.O. 11/7/2025
 Director 11/7/25
 10/7/25
 11/7/25
 11/7/25

Am/Ur