



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F.6/DFS/MS/2025/CNG/WZ/251

Dated: 15/05/2025

FIRE SAFETY CERTIFICATE

Certified that the **CNG Filling Station (IGL) at Site No.45, Mangolpuri Industrial Area, Phase-II, Outer Ring Road, Delhi-110086**, comprised of **Single Story building** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/2022/CNG/WZ/182 dated 21.04.2022**. The premises was re-inspected by the officer concerned of this department on **06.05.2025** in the presence of **Mr. Gaurav Sharma (DGM)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy "**CNG Filling Station Group 'J'**" with effect from 15/05/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/05/2025 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to :-

1. Sh. Ajay Khatri, GM (Fire & Safety) IGL Bhawan Plot No.4, Community Centre, R.K. Puram, Sector-9, New Delhi-110022.
2. The Manager, CNG Filling Station (IGL) at Site No.45, Mangolpuri Industrial Area, Phase-II, Outer Ring Road, Delhi-110086.

Conditions for the validity of fire safety certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on.
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : CNG Filling Station (IGL) at Site No.45, Mangolpuri Industrial Area, Phase-II, Outer Ring Road, Delhi-110086.
2. Type of Occupancy : CNG Filling Station Group 'J'
3. Type of Case : Renewal (Single Story Building)
4. Details of Previous NOC : F.6/DFS/MS/2022/CNG/WZ/182 dated 21.04.2022
5. Fire Safety directives letter No : NBC Part-IV
6. Date of inspection : 06.05.2025
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Mr. Gaurav Sharma (DGM)
9. Year of Construction : 2000
10. Applicant's letter No. : OD No.211 dated 04.04.2025.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width 	8.m	30m	MR
	<ul style="list-style-type: none"> Gate width 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Width of internal road 	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Basements 	-NA-	-NA-	-NA-
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Basements 	-NA-	-NA-	-NA-
	c. Protection of exits			
	Fire check door	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization 	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	1.0m	1.0m	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Sealing of electrical shafts 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fire Rating of shaft door 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Water Curtain 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Fire Dampers 	-NA-	-NA-	-NA-
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Upper floors 	-NA-	-NA-	-NA-
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	26nos.	26nos.	MR
	<ul style="list-style-type: none"> Types 	ABC/CO2	07 trolley- 75 kg each, 16-DCP & 03 Co2	MR
	<ul style="list-style-type: none"> ISI marking 	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Length of hose reel hose 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Nozzle diameter 	-NA-	-NA-	-NA-
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors 	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Location of Main Panel 	-NA-	-NA-	-NA-

By 

N/25


	<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power Hooters' Location 	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			-NA-
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants			-NA-
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	-NA-	-NA-	-NA-
12.	Yard Hydrants			-NA-
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	-NA-	-NA-	-NA-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	-NA-	-NA-	-NA-
15.	Exit Signage.	-NA-	-NA-	-NA-
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	-NA-	-NA-	-NA-
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel 	-NA-	-NA-	-NA-

cm


20.	<ul style="list-style-type: none"> PA System Panel Battery backup Building Floor Plans 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F.6/DFS/MS/2022/CNG/WZ/182 dated 21.04.2022** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.


 Signature of the Inspecting Officer
 Name **Ajay Kumar Sharma**
 Designation **ADO(Rohini)**

DO (NW)


06/05/2025


By Cfo (WZ)


8/5

DCFO/1362-NW

Dated 09/05/25

Cfo


10/5/2025

Director


13/5/25


14/5/25

FT letter is put up for kind perusal and signature please.


14/5/25


15/5/25