



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**



NO. F-6/DFS/MS/CNG/2025/WZ/ 200

Dated: 30/04/2025

To,

Sh. Ajay Khatri,  
GM (Fire & Safety),  
IGL Bhawan, Plot No. 4, Community Center,  
Sec. 9, R.K. Puram, Delhi-110022.

**Sub: - Regarding issuance of Fire Safety Certificate in r/o CNG Station located at Plot No. 22, Facility Area-2, Sector A-7, Narela, Delhi- 110040.**

Sir,

This has reference to your letter no. IGL/F&S/2025/15/25/1 dated 02/04/2025 received through outdoor diary no. 213 dated 04.04.2025, on the subject cited above, it is to inform you that above mentioned CNG station was visited by officer concerned of this department on 23.04.2025 in the presence of Sh. Keshav. Your request for renewal of Fire Safety Certificate is rejected as following shortcoming has been observed.

1. MOEFA found provided but not functional.
2. Water Mist cum foam trolley found not functional.

Keeping in view of above Fire Safety Certificate cannot be considered at this stage. You are requested to apply again after compliance of above mentioned shortcoming for further consideration in this matter.

Yours faithfully

(Atul Garg)  
Director  
Delhi Fire Service

*[Handwritten signature of Atul Garg]*  
*[Handwritten signature]*  
*[Handwritten signature]*  
23/4