



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

c/09

No. F6/DFS/MS/2025/CC/ 90

Dated: 19/08/2025

To

The Executive Engineer (Bldg.)-I,
Keshavpuram Zone, MCD, Delhi.

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s Coaching Centre located at Plot No-02, Second Floor, FD-Block, Pitampura, Delhi-110034.

Sir,

Please refer to your online ID No- 70000185 dated 25/07/2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officers concerned of this department on 05/08/2025 to verify the fire safety arrangements installed in the building. At the time of inspection Sh. Sumit (Attendant) was also present at site. During the course of the inspection it was observed that the building is comprised of basement, ground & 02 upper floors but coaching center purposed at second floor only. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. There are two staircase is provided having width of 1.40m & 1.30m against the requirement of 1.50m each.
2. The width of corridor is 01m provided against the requirement of 1.50m.
3. The width of classroom doors provided is 82cm against the requirement of 1.20m.
4. Smoke management system is not provided.
5. Hose reel hose is not provided.
6. Terrace level fire pump capacity of 450 LPM is not provided.
7. Terrace level fire water tank 10,000 Ltr is not provided.
8. Exits & floor signs is not provided.
9. Standby power supply is not provided.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the abovementioned shortcomings under intimation to this department; till such time running of educational building (coaching centre) is at your own risk & responsibility.

Yours faithfully

Virendra Singh
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. M/s Coaching Centre located at Plot No-02, Second Floor, FD-Block, Pitampura, Delhi-110034.