



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/EH/NDZ/2026/ 414

Dated: - 30/04/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi - 110001.

Sub: Regarding renewal of FSC in r/o M/s Cocorico Cafe and Bar, 2206, Ground Floor, Raj Guru Road, Paharganj, New Delhi - 110055.

Sir,

Please refer to online application No. 2026040304217 dated 03/04/2026, on the subject cited above. In this connection, it is to inform you that the said restaurant was inspected by the officers concerned of this department on 09/04/2026 in the presence of **Sh. Amit Kumar, Manager** and following shortcomings were observed: -

1. Smoke Management System provided but found non-functional.
2. Overhead Water Storage provided 10,000 Ltrs. against required capacity of 20,000 Ltrs.

Keeping in view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands rejected. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours faithfully,


(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

OIC BSI

Copy to: -

1. The Chairman, NDMC, Palika Kendra, Parliament Street, New Delhi - 110001
2. The Manager, M/s Cocorico Cafe and Bar, 2206, Ground Floor, Raj Guru Road, Paharganj, New Delhi - 110055.