



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

75  
आज़ादी का  
अमृत महोत्सव

No. F6/DFS/MS/EH/SZ/2025/284

Dated: 23/06/2025

To  
The Joint Commissioner of Police,  
Office of Joint commissioner of Police: Licensing,  
1st Floor, P S Defence Colony, New Delhi.

**Sub: - Regarding grant of Fire Safety Certificate in r/o M/s Coffee Island (A Unit of Vita Nova Gourmet Pvt. Ltd) located at M-63, Upper Ground floor, M – Block, Greater Kailash, New Delhi-48.**

Sir,

With reference to the etl.mcdonline application no. 2025041906714 on the subject cited above, it is informed that the said restaurant was inspected by officer concerned of this department on 16.06.2025 in the presence of Mr. Saurav (Manager) and it was observed that the restaurant is running at Upper Ground floor of the building is comprised of Basement + Upper Ground + 03 upper floors. During the inspection the following shortcomings were observed:

1. Main exit does not have firm steps.
2. Alternate exits width not meeting the requirements.
3. MOEFA (Manual Operated Electrical Fire Alarm System) found non functional.
4. Fire Pump having capacity of 450 LPM found not provided.
5. Overhand tank capacity of 20,000 liters for firefighting found not provided.
6. Access to the terrace tank is through other's property.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)  
Director  
Delhi Fire Service

c 18/6