



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/Hospital/NDZ/2025/ 607

Dated: 18/11/2025

FIRE SAFETY CERTIFICATE

Certified that the College of Nursing (Florence Nightingale) at GTB Hospital, Shahdara, Delhi, building comprised of basement, ground plus three upper floors owned/occupied by GTB Hospital was issued FSC vide letter No. F6/DFS/MS/Hospital/NDZ/2022/33 dated 21/01/2022. The hospital building was re-inspected by the officers concerned of this department on 28/08/2025 in presence of Mr. Jagbir Singh, A.E (E) and observed that all the fire prevention and fire safety requirements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class Group - C "**Institutional Building**" with effect from 18/11/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 18/11/2025 at New Delhi by.

(Dr. S.K. Tomar)

Dy. Chief Fire Officer (NDZ)

Delhi Fire Service

Copy to: -

1. The Medical Superintendent, Nursing Homes, Directorate General of Health Services, Govt. of NCT of Delhi, 3rd floor, Delhi Govt. Dispensary Building, S-1, School Block, Shakarpur, Delhi-110032.
2. The Executive Engineer (E), HMED(East), PWD, GTB Hospital complex, Shahdara, Delhi-110095.
3. The Medical Superintendent, College of Nursing (Florence Nightingale) at GTB Hospital, Shahdara, Delhi.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	College of Nursing (Florence Nightingale) at GTB Hospital, Shahdara, Delhi.		
2	Building is comprised of	Ground plus three upper floors		
3	Type of occupancy	Institutional Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/Hospital/NDZ/2022/33 dated 21/01/2022		
6	Fire safety directives letter no.	N/A		
7	Date of inspection	28/08/2025		
8	Name of the inspecting officers	Yashwant Singh Meena, A.D.O (LN) & Ashok Kumar Jaiswal D.O (East)		
9	Name of the designation of officer from the building side	Mr. Jagbir Singh, A.E (E)		
10	Year of construction	1998		
11	Applicant's letter no.	54(1)/A.E (E)/HE-1/HMESD/GTBH/2025/23 dated 20/03/2025		
S. No.	Minimum standard of fire prevention and fire safety U/R 33	Requirement/ BBL	Provided at site	Remarks MR/NMR
1.	Access to Building:			
	A Road width	12 mtrs.	18 mtrs.	MR
	B Gate width	4.5 mtrs.	5.25 mtrs.	MR
	C Width of internal road	06 mtrs.	06 mtrs.	MR
2.	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	02 nos.	02 nos.	MR
	Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.5 mtrs.	1.5 & 1.44 mtr.	MR (Old accepted)
	Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	Required	Provided	MR
	b Pressurization	Required	Provided	MR
	D No. of continuous staircases to terrace	02 nos.	02 nos.	MR
	E Width of corridor	1.5 mtrs	1.5 mtrs	MR
	F Door size	1.5 mtrs.	1.5 mtrs	MR
3.	Compartmentation:			
	A Fire check door	Required	Provided	MR
	B Sealing of electrical shafts	Required	Provided	MR
	C Fire rating of shaft door	Required	Provided	MR
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	Required	Provided	MR
4.	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	Required	Natural	MR
5.	Fire Extinguisher:			
	A Total numbers	25 nos.	30 nos.	MR
	B Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C ISI marking	ISI Marked	ISI Marked	MR

6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	01 no.	01 no.	MR
	B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	Heat & Smoke	Provided	MR
	B	Location of main panel	Basement	Provided	MR
	C	Location of repeater panel	Security room	Provided	MR
	D	Alternate source of power	Battery & DG Set	Provided	MR
	E	Hooters	Near Staircases	Provided	MR
8	MOEFA:		Required	Provided	MR
9	Public Address System:		Required	Provided	MR
10	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	Required	Provided	MR
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	100 mm	100 mm	MR
	B	Number of hydrants per floor	02 no	02 no	MR
	C	Hose box	02 no	02 no	MR
12	Yard Hydrants:				
	A	Total number of hydrants	02 no	02 no	MR
	B	Hose box	02 no	02 no	MR
13	Pumping Arrangements:				
1	Ground level		Common GTB Hospital		
	A	Discharge of main pump	2850 LPM	2850 LPM	MR
	B	Head of main pump	70 mtrs	70 mtrs	MR
	C	Number of main pumps	01 No.	01 No.	MR
	D	Jockey pump out put	240 LPM	240 LPM	MR
	E	Jockey pump head	70 mtrs	70 mtrs	MR
	F	Standby pump out put	2850 LPM	2850 LPM	MR
	G	Standby pump head	70 mtrs	70 mtrs	MR
	H	Auto starting /manual stopping	Required	Provided	MR
2	Terrace Level				
	A	Discharge of pump each block	450 LPM	450 LPM	MR
	B	Head of the pump	40 mtrs.	40 mtrs.	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting:		Common GTB Hospital		
	A	Underground tank capacity	N/A	1,00,000 liters	MR
	B	Draw-off connection	N/A	N/A	N/A
	C	Fire service inlet	N/A	N/A	N/A
	D	Access to tank	N/A	N/A	N/A
	E	Overhead tank capacity	10,000 liters	10,000 liters	MR
15	Exit Signage:		Required	Provided	MR

16	Provision of Lifts:					
	A	Pressurization of lift shaft	Required	Provided	MR	
	B	Pressurization of lift lobby	Required	Provided	MR	
	C	Communication in lift car	Required	Provided	MR	
	D	Firemen's grounding switch	Required	Provided	MR	
	E	Lift signage	Required	Provided	MR	
17	Standby Power Supply:		Required	Provided	MR	
18	Refuge Area:					
	A	Total area	N/A	N/A	N/A	
	B	Location	N/A	N/A	N/A	
19	Fire Control Room:					
	A	Detector system panel	Required	Provided	MR	
	B	Flow switch panel	Required	Provided	MR	
	C	PA system panel	Required	Provided	MR	
	D	Battery backup	Required	Provided	MR	
	E	Building floor plans	Required	Provided	MR	
20	Special Fire Protection systems for protection of special Risks, if any:					N/A
	Provided for HT/LT panel					

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of the FSC issued vide letter no. F6/DFS/MS/Hospital/NDZ/2022/33 dated 21/01/2022, renewal under Rule 35(6) of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer
 Name : Yashwant Singh Meena
 Designation: ADO /Laxmi Nagar

Signature of the Inspecting Officer
 Name : Ashok Kumar Jaiswal
 Designation: Divisional Office/ East

Dy. CFO (NDZ)

LVP
 30/09/25

Principal Director

Dy. CFO to Secy.

Dy. CFO (NDZ)

15/10/25

ADO (NDZ)
 16/10/25

ADO (NDZ)

As approved, it is put up for

Dy. CFO (NDZ)

13/10/25

ADO (NDZ)
 17/11/25

ms