

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE**  
**CONNAUGHT PLACE: NEW DELHI-110001**

No. F.6/DFS/MS/2025/SZ/293

Dated: 19 / 06 / 2025

To

The Asst. Inspector General (SPU-III),  
Special Protection Group,  
Cabinet Secretariat, New Delhi.

**Sub: Renewal of Fire Safety Certificate in r/o Community Facility at Residential Cum Training Complex for SPG, Plot No. 21, Sector-21, Dwarka, New Delhi-110077**

Sir,

This has reference to your letter received in this department vide outdoor diary No. 2096 dated 26/05/2025, on the subject above. In this connection, the said premise was inspected by the officer concerned of this department on 03/06/2025 in the presence of Sh. Vijay Kr. Sharma, from fire safety point of view. During course of inspection, the shortcomings observed are as below: -

1. Manual call points found non-functional at some locations.
2. Lift signage found removed.

In view of the above, application for renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

Ph. 011-23414000