



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

349

No. F6/DFS/MS/NDZ/C.Hall/2025/ 349

Dated: 26/07/2025

To,

The Secretary,
Community Hall of Joint Forum,
Vasundhara Enclave, Delhi-110096.

Subject: - Regarding grant of Fire Safety Certificate in r/o Community Hall of Joint Forum, Vasundhara Enclave, Delhi-110096.

Sir,

This has a reference to Outdoor diary no. 3460 dated 07/07/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 12/07/2025 in the presence of Mr. J.P Sharma (President) and observed that building comprised of Basement & Ground floor only.

Following shortcomings were observed during time of inspection:

1. First-aid-Hose Reel provided but not functional.
2. Fire pump of capacity 900 LPM provided but found not functional.
3. Overhead tank capacity of 10,000 liters provided against the requirement of 25,000 liters.
4. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

25/7/2025

(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

1. The Executive Engineer (Bldg), Municipal Corporation of Delhi, Plot No. 419, Patparganj Industrial Area, Delhi -110092.