

C/10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No F6/DFS/MS/SZ/2026/28

Dated 27/01/2026

To,

The Executive Engineer (E)<Email: eecl10@adda.org.in>
Delhi Development Authority,
Electrical Division- 10,
B2B, Janakpuri, New Delhi-110058.

Subject: Issuance of Fire Safety Certificate in r/o Community Hall, Pocket-3 Sector-19 Dwarka New Delhi.

Sir,

Please refer to letter No. F10(14/EE(E)/ELD-10/DDA/25-26/929 dated 09/12/2025 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned of this department on 14/01/2026 in the presence of Caretaker from fire safety point of view.

During the course of inspection following shortcomings were observed:

1. Fire Check Door found damaged.
2. Hose Reels & Hydrants system found nonfunctional.
3. MOFIA found nonfunctional.
4. Terrace Pumps found nonfunctional.
5. Overhead Tank found empty
6. Exit signs found removed at some places.

You are requested to comply the abovementioned shortcomings under intimation to this department. In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(A.K. MALIK)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

929.