

e 94

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**


No. F6/DFS/MS/2025/ School/ **996**

Dated: **13/08/2025**

**FIRE SAFETY CERTIFICATE**

Certified that the **Convent of Jesus and Mary**, located at 01 Bangla Sahib Road, New Delhi comprised of Gr. + first floor, was earlier issued NOC vide letter no. **F6/DFS/MS/2022/School/NDZ/457 dated 26.04.2022**. Now, the said premises was re-inspected by the officers concerned of this department on 23-07-2025 in the presence of Principal madam and found that the said block has complied with the fire prevention and fire safety requirements in accordance with **Director of education circular no. F16/Estate/CC/Fire safety 2011/3298-3398 dated 01.03.2011** and that the premises is fit for occupancy of class Group B "Educational Building" Sr. Secondary Block (Ground + 01 upper floor) only with effect from **13/08/2025** for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on **13/08/2025** at New Delhi by. S

  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service  
✓

Copy to:-

1. The Chief Architect , NDMC, Palika Kendra, New Delhi.
2. Director of Education, Govt. of NCT, Old Secretariat, Delhi.
3. The Principal, CONVENT OF JESUS AND MARY, 01 Bangla Sahib Road, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided there in shall be maintained in good working condition at all time. This FSC is valid only for Sr. Secondary block ground and first floor.
2. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The compliance with regards to electrical installation, structural stability, set back area , occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. The trained fire fighting staff should be available round the clock.
6. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. Any flammable material for interior decoration shall strictly prohibited.



# INSPECTION REPORT

1.	Name & address of the building	Covent of Jesus and Merry school situated 01 Bangla Sahib Road , New Delhi
2.	Type of occupancy:-	Educational group -B Senior secondary Block – Gr. + 01 upper floor
3	Type of case:-	Existing building block
4	Details of previous FSC:-	No. F6/DFS/MS/2022/School/NDZ/457 dated 26.04.2022
5	Fire safety directives No.-	F6/DFS/MS/BP/92/17 dated 03.01.1992
6	Date of inspection:-	23.07.2025
7	Name of the inspecting officer:-	Sh. Ravinder Singh (ADO/CC) Sh. Rajinder Atwal , DO ( CD)
8	Name & designation of officer From the building side:-	<u>Principal</u>
9	Year of construction:-	N/A
10	Applicant's letter No:-	Letter no. nil dated 11.07.2025 & DFS diary 3680 dated 11.07.2025

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	06mtr	06 mtr.	MR
	2) Gate width	05 mtr	Provided	MR
	3)Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	<b>A. Number of staircases</b>			
	Upper floor	04nos	04 nos	MR
	Basements	N/A	N/A	N/A
	<b>B. Width of staircase</b>			
	Upper floors	2.0m 1.0m, .02 of 75m ( spiral )	2.0m 1.0m, 02 of .75m( spiral )	MR
	Basements	N/A	N/A	N/A
	<b>C. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>D. No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	<b>E. Width of corridor</b>	N/A	N/A	N/A
	<b>F. Door size</b>	01 mtr.	01 mtr.	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A



M/39

	4) Water curtain	N/A	N/A	N/A
4.	5) Fire Dampers	N/A	N/A	N/A
	<b>Smoke Management System</b>			
	1) Basements			
	2) Upper floors	30 ACPH	Mechanical	MR
5.	12 ACPH	Natural	MR	
	<b>Fire Extinguishers</b>			
	1) Total numbers			
	2) Types	12 Nos.	12 Nos.	MR
	3) ISI marking	ABC & CO2	ABC & CO2	MR
6.	<b>First-Aid Hose Reel</b>	Required	Provided	MR
	1) Total number at each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
7.	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	<b>MOEFA</b>	N/A	N/A	N/A
9.	<b>Public Address System</b>	N/A	N/A	N/A
10.	<b>Automatic Sprinkler System</b>	N/A	N/A	N/A
	1) Basement			
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A

2/40

	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: ABC & CO <sup>2</sup>			N/A

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules if agreed, we may renew the FSC issued vide letter No F6/DFS/MS/2022/School/NDZ/457 dated 26.04.2022, under Rule 35 of the Delhi Fire Service Rules 2010, Accordingly, FSC is recommended for approval and signature please.

Signature of the Inspecting Officer

Name :- Rajinder Atwal  
Designation :- DO (CD)

Signature of the Inspecting Officer

Name :- Ravinder Singh  
Designation :- ADO (CC)

*[Signature]*  
C.F.O.

*[Signature]*  
25/07/25

*[Signature]*  
6/01/2025

*[Signature]*  
Principal Director

*[Signature]*  
CFO to Secy.

*[Signature]*  
07/08/25

*[Signature]*  
11/8/2025

*[Signature]*  
ADP (cc)

*[Signature]*