



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/Hospital/2024/SZ/172

Dated: 17/04/2024

To

Sh. Satesh Kumar,  
ASO (Fire Safety),  
Administrative Block,  
AIIMS, New Delhi-110029

Sub: **Renewal of Fire Safety Certificate in r/o Convergence Block, AIIMS Complex, Ansari Nagar, New Delhi-110029**

Sir,

This is with reference to the email received from Id: [satesh@aiims.gov.in](mailto:satesh@aiims.gov.in) dated 10/03/2025, on the subject cited above. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on dated 02/04/2025 to see the performance of fire protection measure provided. Sh. Harinder Singh (Dy. CSO) & yourself was presence at the time of inspection. During the inspection, the shortcomings observed are as below.

1. Escape route (stairs) in basement found closed with lock & key.
2. Corridors found encroached/blocked with almirah.
3. Electrical shaft found unsealed vertically & horizontally at some levels.
4. Lift signage found removed at some location.
5. Waste material lying at the terrace is fire hazards.

In view of the above, the application for renewal of Fire Safety Certificate is rejected. You are advised to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

  
17/04/2025  
(Virendra Singh)  
Chief Fire Officer  
Ph. 011-23414333  


Copy to: -

1. The Director, All India Institute of Medical Science, Ansari Nagar, New Delhi-110029