

CF 75

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hosp./2025/SZ/ 364

Dated: 09/06/2025

FIRE SAFETY CERTIFICATE

Certified that the **Convergence Block (New PC Teaching Block)** at AIIMS Complex, Ansari Nagar, New Delhi-110029, Two Basement, Ground + 09 upper floors. owned/occupied by All India Institute of Medical Sciences, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/Hospital/2021/SZ/534 dated 27/10/2021. The premise was re-inspected by the officer concerned of this department on 24/05/2025 in the presence of Col. Digvijay Singh (CSO) and found that said premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said building/premises is fit for occupancy class "**Institutional, Group-C**" (Hospital) with effect from 09/06/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 09/06/2025 at New Delhi by

Vul
6/6/2025
(Virendra Singh)
Chief Fire Officer
Ph. 011-23414333
ACF

Copy to: -

1. Col. Digvijay Singh, Chief Security Officer, Administrative Block, AIIMS Complex, New Delhi-110029
2. The Executive Engineer (Elect), Engineering Service Department, AIIMS Complex, New Delhi-110029

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. Basement shall be used strictly in accordance with Building Bye-Laws.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, prior to its expiry.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name & Address of the Building	Convergence Block (New PC Teaching Block) AIIMS Complex, Ansari Nagar, New Delhi-110029		
2	Type of Occupancy	Institutional building, "Group-C" (Hospital)		
3	Building Comprised of	Two Basement, Ground + 09 upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/Hospital/2021/SZ/534 Dt. 27/10/21		
6	Fire Safety Directives Letter No	F.6/DFS/MS/BP/2011/1203 dated 14/06/2011		
7	Date of Inspection	24/05/2025		
8	Name of the Inspecting Officers	ADO (SJ)		
9	Name & Designation of Officers from the building side	Col. Digvijay Singh (CSO)		
10	Year of construction	2013		
11	Applicant letter No.	Email dated 28.04.2025		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	12 mtr	12 mtr	MR
	• Gate width	4.5 mtr	6 mtr	MR
	• Width of internal road	6 mtr	6 mtr	MR
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	Provided	MR
	➤ Basement floor.	02 Nos	Provided	MR
	b) Width of Staircase			
	➤ Upper floors	2 mtr (each)	2 mtr (each)	MR
	➤ Basement floor	2 mtr (each)	2 mtr (each)	MR
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	Required	Provided	MR
	d) No. of continuous staircase to terrace	02 Nos	Provided	MR
	e) Width of corridor	1.5m	Provided	MR
	f) Door size	1m	1m x 1.25m	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	01 Hr.	Provided	MR
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	Required	Provided	MR
4.	Smoke Management system.			
	• Basement	30 ACPH	Provided	MR
	• Upper floors/Audi.	12 ACPH	Provided	MR
5.	Fire Extinguishers.			
	• Total numbers	54 Nos	60 Nos	MR
	• Types	ABC/CO ₂	ABC & CO ₂	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	2 Nos	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

7	Automatic fire detection & alarming system.			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	-NA-	-NA-	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	All Areas	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper floors	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	150mm	Provided	MR
	• Number of Hydrant per floor	02 Nos	Provided	MR
	• Hose box.	02 Nos	Provided	MR
12.	Yard Hydrants.			
	• Total number of hydrants.	05 Nos	08 Nos	MR
	• Hose box.	05 Nos	08 Nos	MR
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	2850 LPM	2850 LPM	MR
	➤ Head of main pump.	85m	85m	MR
	➤ Number of main pumps.	02 Nos	02 Nos	MR
	➤ Jockey Pump output.	2 x 280 LPM	Provided	MR
	➤ Jockey Pump head.	85m	85m	MR
	➤ Standby Pump output.	2850 LPM	2850 LPM	MR
	➤ Standby Pump head.	85m	85m	MR
	➤ Auto Starting/Manual Stopping.	Required	Provided	MR
	➤ Pump house access.	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump.	-NA-	-NA-	-NA-
	➤ Head of pump.	-NA-	-NA-	-NA-
	➤ Power supply.	-NA-	-NA-	-NA-
	➤ Auto starting of pump.	-NA-	-NA-	-NA-
14.	Captive water storage for firefighting.			
	• Underground tank capacity.	2,00,000 Ltr	Provided	MR
	➤ Draw-off connection.	Required	Provided	MR
	➤ Fire Service Inlet.	Required	Provided	MR
	➤ Access to tank.	Required	Provided	MR
	• Overhead tank capacity.	20, 000 Ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	Required	Provided	MR
	• Pressurization of lift lobby.	Required	Provided	MR
	• Communication in lift car.	Required	Provided	MR
	• Fireman's switch.	Required	Provided	MR
	• Lift signage.	Required	Provided	MR
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	443.5 m ²	Provided	MR
	• Location	7 th Floor	Provided	MR

N-23

19.	Fire Control Room.	Provided at Ground Floor		
		Required	Provided	MR
	• Detector system panel.	Required	Provided	MR
	• Flow switch panel.	Required	Provided	MR
	• PA system panel.	Required	Provided	MR
	• Battery backup.	Required	Provided	MR
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of Special Risk, if any.	LT. HT & Transformer are provided with ABC & CO ₂ fire extinguishers.		
				MR

The fire protection systems provided in the premises/building were checked, tested at random and found functional at the time of inspection. The shortcomings issued vide letter No. F.6/DFS/MS/Hospital/2024/SZ/172 dated 17/04/2025 found rectified.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/Hospital/2021/SZ/534 dated 27/10/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for perusal/approval & signature please.

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD)

CFO/MS/

26/6/2025

DO (SD)

3/6/25

ADO (SJ)

Sir,

F.T Letter is put up for your signature

CFO/MS/ 6/6/2025
M.S. call

Signature
5/6/25