

234

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F.6/DFS/MS/2025/BNOT/03

Dated 27/01/2025

To,

The Manager,
Capital City Hospitality Pvt. Ltd.
Lacordiall, Banquet, shop no. 1 to 10,
Second floor, Cross River Mall, CBD
Ground, Shahdara, Delhi-110032.

Sub:- Regarding renewal of FSC in r/o Capital City Hospitality Pvt. Ltd. Lacordiall, Banquet, Shop no. 1 to 10, Second floor, Cross River Mall, CBD Ground, Shahdara, Delhi-110032.

Sir,

This has reference to your Online Id 2025011300446 dated 13/01/25, on the subject cited above. In this connection it is to inform that the site was visited by the officer concerned of this department on 22/01/2025 in the presence of Mr. Sandeep (Manager) & Mr. Himanshu (Fire man), and the following shortcomings were observed:-

1. FCD found removed from staircase & lift lobby,
2. Pressurization at staircase found nonfunctional and found removed from lift shaft & lift lobby.
3. Detectors found nonfunctional.
4. MCP & PA system found nonfunctional.
5. Lift signages " not to use lift in case of fire" found removed.
6. Flow switch panel in FCR is found removed.

In view of above , the case is rejected and FSC cannot be renewed at this stage.

Yours faithfully

(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to :

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi online ID No. 2025011300446 dated 13/01/25