



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

2/40



No. F6/DFS/MS/School/SZ/2025/ 276

Dated: 24/04/2025

To

The Principal,  
Cosmos Public School,  
Molarband Ext., Tajpur,  
Badarpur, New Delhi-110044.

**Sub:-** Regarding issuance of Fire Safety Certificate in respect of **Cosmos Public School** located at **Molarband Ext., Tajpur, Badarpur, New Delhi-110044.**

Sir,

With reference to letter bearing outdoor diary no. 9845 dated 03.12.2024 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 05.03.2025 in the presence of Mr. Mohan Prasad (Guard/Caretaker) and it was observed that the building is comprised of Basement + Ground + 03 upper floors. During inspection following shortcomings were observed:-

1. Alternate staircase of minimum width 0.75 meter in basement has not been provided.
2. Hose reel found non functional.
3. Automatic Sprinkler system found non functional in basement.
4. Fire pump found not functional.
5. Exit signages found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.