



c-2)

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/School/SZ/2025/ 1014

Dated: 19/08/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **C.P.S. Little Champ School** located at **Shakti Vihar, Meethapur Extn., Badarpur, New Delhi-44**, school is running at Ground + 01 upper floor of the building which is comprised of Ground + 03 upper floors, owned & occupied by **C.P.S. Little Champ School** have complied with the fire prevention and fire safety requirements in accordance with the circular no. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Directorate of Education and verified by officer concerned of Delhi Fire Service on 11.08.2025 in the presence of Mrs. Rahana Khan (Principal) and found that the building/premises (**Ground + 01 upper floors**) is fit for occupancy of **Group B "Educational Building"** with effect from 19/08/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on... 19/08/2025 ...at New Delhi by

Yours Faithfully

  
(Virender Singh)  
Chief Fire Officer

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
2. The Principal, C.P.S. Little Champ School located at Shakti Vihar, Meethapur Extn., Badarpur, New Delhi-44.

**Conditions for the validity of Fire Safety Certificate**

1. **This Fire Safety Certificate is valid for Ground + 01 upper floor only, 2<sup>nd</sup> and 3<sup>rd</sup> floor shall remain sealed.**
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub Rule (1) of Rule 37] along with a copy of this certificate, six months prior to its expiry.



2/7

### INSPECTION REPORT

1	Name and address of the building:	C.P.S. Little Champ School located at Shakti Vihar, Meethapur Extn., Badarpur, New Delhi-44.		
2	Building is comprised of	Ground + 3 upper floors School running Ground + 01 upper floor of the building & 2 <sup>nd</sup> & 3 <sup>rd</sup> floor sealed/closed by MCD.		
3	Type of occupancy	Educational, Group-B (School)		
4	Type of case:	New case		
5	Details of previous FSC	Nil		
6	Fire safety directives no.:	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of inspection:	11.08.2025		
8	Name of the inspecting officer:	ADO Rajesh Kumar Shukla (M. Road)		
9	Name and designation of the officer from the building side:	Mrs. Rahana Khan (Principal)		
10	Year of construction:	2009		
11	Reference letter no.:	Outdoor diary no. 1630 dated 14.05.2025		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement as per circular dated 01.03.2011	Provide at site	Remarks MR/NMR
1	<b>Access to Building</b>			
	A Road width	Accessible	Accessible	MR
	B Gate width	NA	NA	NA
	C Width of internal roads	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	A No. of staircase:			
	a) Upper floor	2 nos.	2 nos.	MR
	b) Basements	NA	NA	NA
	B Width of the staircase:			
	a) Upper floor	1.50 m & 0.75 m	1.50 m each	MR
	b) Basements	NA	NA	NA
	C Protection of exits			
	a) Fire check door	NA	NA	NA
	b) Pressurization	NA	NA	NA
	D No. of continuous staircase to terrace:	01 no.	Provided	MR
	E Width of the corridor	1.5 mtrs	Provided	MR
	F Door size	1.0 mtrs. (for class room)	1.0 mtrs. (for class room)	MR
3	<b>Compartmentation:</b>			
	A Fire check doors	NA	NA	NA
	B Sealing of electrical shafts	NA	NA	NA
	C Fire rating of shaft doors	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	<b>Smoke Management System:</b>			
	A Upper floors	NA	NA	NA
	B Basements	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	A Total numbers	06 nos.	Provided	MR
	B Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	C ISI marking	Required	Provided	MR

BL

2/8

6	<b>First Aid Hose reel</b>			
A	Total no. at each floor	01 no.	01 no.	MR
B	Length of hose reel	30 mtrs	30 mtrs	MR
C	Nozzle diameter	5 mm	5 mm	MR
7	<b>Automatic Fire Detection and Alarm System (ADAS)</b>			
A	Type of detectors	NA	NA	NA
B	Location of main panel	NA	NA	NA
C	Location of repeater panel	NA	NA	NA
D	Alternate power source	NA	NA	NA
E	Hooter's location	NA	NA	NA
8	<b>MOEFA</b>			
9	<b>Public Address System</b>			
10	<b>Automatic Sprinkler System</b>			
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA
C	Sprinklers above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
A	Size of the riser/down comer	NA	NA	NA
B	No. of hydrants per floor	NA	NA	NA
C	Hose box	NA	NA	NA
12	<b>Yard Hydrants</b>			
A	Total no. of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
13	<b>Pumping Arrangements</b>			
A	<b>Ground Level</b>			
a)	Discharge of main pump	NA	NA	NA
b)	Head of main pump	NA	NA	NA
c)	Number of main pump	NA	NA	NA
d)	Discharge of jockey pump	NA	NA	NA
e)	Head of jockey pump	NA	NA	NA
f)	Discharge of standby pump	NA	NA	NA
g)	Head of standby pump	NA	NA	NA
h)	Auto starting/ manual stopping	NA	NA	NA
B	<b>Terrace Level</b>			
a)	Discharge of terrace pump	450 LPM	450 LPM	MR
b)	Head of terrace pump	40 mtrs	40 mtrs	MR
c)	Alternate power supply	Required	Provided	MR
d)	Auto starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for Fire Fighting</b>			
A	Underground tank capacity	NA	NA	NA
B	Draw off connection	NA	NA	NA
C	Fire service inlet	NA	NA	NA
E	Access to tank	NA	NA	NA
D	Overhead tank capacity	10,000 liters	Provided	MR
		Required	Provided	MR
15	<b>Exit Signage</b>			
16	<b>Provision of lift</b>			
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Fireman switch	NA	NA	NA
E	Lift signage	NA	NA	NA
17	<b>Standby Power Supply</b>			



18	Refuge Area			
A	Location	NA	NA	NA
B	Total area	NA	NA	NA
19	Fire Control Room			
A	Fire detection system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	P A system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plan	NA	NA	NA
20	Special Fire Protection for special risk if any			

**Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided Not Functional (PNF).**

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in Directorate of Education circular no. 3298 to 3398 dated 01.03.2011, it is recommended to grant Fire Safety Certificate.

Signature of the Inspecting Officer  
 Name Rajesh Kumar Shukla  
 Designation ADO (M. Road)

DO (SD)

CFO

14/8/2015

Principal Director

CFO to Issue.  
 14/8/25

CFO

ADO (M.R.)

Fr is put up ph

18/8/25.

CFO

18/8/2015

MS