

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

No. F.6/DFS/MS/School/2025/SZ/1384

Dated: 09/12/2025

FIRE SAFETY CERTIFICATE

Certified that the CRPF Public School located at Sector 16 B, Dwarka, New Delhi- 110075, comprised of basement (storage), ground floor plus four upper floors, was issued Fire Safety Certificate by this department vide letter No.F.6/DFS/MS/School/SZ/2022/1276 dated 29.11.2022. The school building was re- inspected by the officer concerned of this department on dated 27.11.2025 in the presence of Ms. Meenu Tiwari (Principal), and found that the school building have complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "Educational Building" w.e.f. 09/12/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 09/12/2025 at New Delhi by.


(A.K. Malik)

Dy. Chief Fire Officer
South Zone

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
2. The Principal, CRPF Public School Located at Sector 16 B, Dwarka, New Delhi- 110075.
3. The Executive Engineer (Bldg.), MCD, Civic Centre, New Delhi.

: - for information regarding use of basement.

Conditions for the validity of fire safety certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used as per the BBL/UBBL. Presently basement used for storage only.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

M/31

INSPECTION REPORT

1. Name & address of the building : CRPF Public School at Sec. 16 B, Dwarka, New Delhi- 75.
 2. Building comprised of : Basement, Ground plus four upper floors.
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous NOC/FSC : F.6/DFS/MS/School/SZ/2022/1276 dated 29.11.2022
 6. Fire Safety directives letter No : N/A
 7. Date of inspection : 27.10.2025
 8. Name of Inspecting Officer : A.D.O. R.K. Yadav (DWK)
 9. Name and designation of officers
 From the building side : Ms. Meenu Tiwari (Principal)
 10. Year of Construction: 2010
 11. Applicant's letter No. : CRPFPS/School/Fire Safety/2025-26/2162 dt. 17.11.2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements as per FSC dated 29.11.2022	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 06 m 4.5 m Required	06 m 4.5 m Provided	M/R MR MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 No's 02 No's	04 No's 07 No's	M/R M/R
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.50 m each 1.50 m each	Provided Provided	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	Required	Two	M/R
	e. Width of Corridor	1.50 m	2.06m	M/R
	f. Door Size	1.0 m	1.0m	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Required Required 02 Hours N/A N/A	Provided Sealed 02 Hours N/A N/A	MR MR MR N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	Required Required	Provided Natural ventilation	MR M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	60 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	M/R M/R M/R
6.	First-Aid Hose Ree			
	<ul style="list-style-type: none"> Total numbers at each floor Length of hose reel hose Nozzle diameter 	03 nos. 30 M 5 mm	Provided Provided Provided	M/R M/R M/R

7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	150 mm	MR
	• Number of hydrants per floor	03	03	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	06 nos.	N/A
	• Hose Box	N/A	Provided	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	900 & 180 LPM	Provided	MR
	➤ Head of the pump	40 m.	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	55,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR


N/33

	Standby power supply	Required	DG Set	MR
V/A 18.	Refuge Area.			
	✓ Total Area	N/A	N/A	N/A
	✓ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	Required	CO2, Fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: - As per undertaking submitted by the school management (placed at C- 94) that the school building comprised of basement, ground plus four upper floors, using basement as storage and ground floor to fourth floor are being used exclusively for conducting classes for students.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/SZ/2022/1276 dated 29.11.2022 is **recommended to be renewed** under rule 37, of the Delhi Fire Service Rules, 2010.


Signature of the Inspecting Officer
Name:-R.K. Yadav
Designation: - ADO (DWK)


DO (SW)

RAJINDER ATWAL


Dy. C.S.O. (SZ)


2/12/22
A.K. MALIK

Principal Director

My. C.S.O. to S.S.M.

02/12/22

My. C.S.O. (SZ)


3/12/22
A.K. MALIK

2/12
A.O. (S.M.)