



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/2025/EH/ 313

Dated: 22/07/2025

To

The Dy. Health Officer,
Civil Lines Zone, MCD
16, Rajpur Road, Civil Lines,
New Delhi-110054

Sub: Regarding renewal of fire safety certificate in r/o M/s Mr. Crust Bakers located at Ground Floor, Property No. 2521, Hudson Lane, Kingsway Camp, Delhi-110009

Sir,

This has reference to online MCD Portal ID No. 2025062310471 dated 24/06/2025 on the subject cited above. In this connection, this is to inform you that the said premises was inspected by the officers concerned of this department on 14/07/2025 in the presence of Mr. Kanahiya Kumar (Manager) of the restaurant and the shortcomings observed are as below.

1. The alternate exit found locked/blocked.
2. Hose-reel hose found non-functional.
3. Terrace fire pump was not on auto mode.
4. Exit signage's found removed at some locations.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. Applicant may be requested to rectify the above-mentioned shortcomings under intimation to this department; till such time running of restaurant shall be at the risk and liability of the owner/occupier.

Yours faithfully,


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

01/8/25