



c/30

T-20
13/01/25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/EH/NDZ/2025/ 20

Dated: 13/01/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s. Mr. Crust Bakers, located at Property No. A-18, Ground Floor, Guru Nanak Pura, Laxmi Nagar, Shahdara, New Delhi-110092, running at Ground Floor only, in a building comprised of Basement + Ground + 03 Upper Floor, the building/premises was inspected by the officer concerned of this department on 02/01/2025 in the presence of Sh. Shivam (Manager) and found that the said premises/building have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Assembly" (Group - D) (For Ground Floor Only and valid upto 31/03/2027 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 conditions mentioned below.

Issued on 13/01/2025 at New Delhi by.

(Atul Garg)
Director

Copy to: -

1. The owner/occupier, M/s. Mr. Crust Bakers, located at Property No. A-18, Ground Floor, Guru Nanak Pura, Laxmi Nagar, Shahdara, New Delhi-110092.
2. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. (addlcp.lic-dl@nic.in) w.r. to ID No.- 2024121317997 dated 13/12/2024
3. The Dy. Health Officer, MCD, South Zone, 419, Patparganj, Industrial, , New Delhi 110092.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. At present, Basement is lying vacant.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1.	Name & address of the building	M/s. Mr. Crust Bakers Located at Property No. A-18, Ground Floor, Guru Nanak Pura, Laxmi Nagar, Shahdara, New Delhi-110092.
2.	Type of Occupancy	Assembly Building (Restaurant)
3.	Type of Case	New Case
4.	Details of previous NOC	Nil
5.	Fire Safety directives letter No	NBC Part-IV
6.	Date of inspection	02/01/2025
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	Sh. Shivam (Manager)
9.	Year of Construction	2022
10.	Applicant letter no.	MHA Portal ID No. – 2024121317997 dated 13/12/2024

The said restaurant is running at ground floor, in a building comprised of basement (Vacant), ground and three upper floors. (1st, 2nd & 3rd floor are using by OYO Guest House)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC part-IV Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	9 mts	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	NA	NA	NA
	g. Door Size	2 x 1.50m	2m, 1.5m & 1.25m Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	04 nos.	Provided	MR
	• Types	CO ₂ , ABC	Provided	MR
	• IS marking	type ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	Provided	NA
	• Location of Main Panel	NA	Ground Floor	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	Provided	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	Provided	NA
	• Upper Floor	NA	Provided	NA
	• Sprinkler above false ceiling	NA	Provided	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

N/13

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Earlier all the shortcomings issued by this department have been complied by the restaurant management.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

[Signature]
 Signature of the Inspecting Officer
 Name: Sarabjeet Singh
 Designation: Assistant Divisional Officer

DO (E)

[Signature]
 07/01/2025

Dy. C.F.O. (NDZ) *[Signature]*
 08/01/25

C.F.O. *[Signature]*
 8/01/2025

Dineet Singh *[Signature]*
 8/1/25

kind personal

Director *[Signature]*

Any more *[Signature]* *Dr. R. T. S.*
put up for your
signature please. *[Signature]*
 8/1/25

uploaded
 13/01/25 *[Signature]*