

cl 49

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F.6/DFS/MS/NDZ/2024 / 08

Dated: 02/01/2025

To

Sh. M.L. Prasanna Kumar,  
EE (E), ESD, Council of Scientist & Institute Research,  
Complex Pusa, New Delhi.

**Sub:- Regarding renewal of FSC in r/o of CSIR Anusandhan Bhawan, 2, Rafi Marg, New Delhi.**

Sir,

This has reference to your letter no. nil dated 19.11.2024, on the subject cited above. In this regard, it is to inform that the site was inspected by the officers concerned of this department on 19.12.2024, in the presence of Sh. Arun Misra, SE & Sh. Prasanna, and the following shortcomings were observed:-

1. Detectors are not provided at some offices.
2. MOEFA is not provided in basement.
3. Temporary offices found constructed at terrace level, accordingly approval of terrace floor ( fifth floor) from building sanctioning authority is required to be submitted.

In view of above shortcomings FSC can not be issued. Further, the occupancy of building /premises, in absence requisite fire & life safety arrangements, shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

**Copy to :**

The Chief Architect,  
New Delhi Municipal Council, Palika Kendra, New Delhi.