



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

C-113
Dated: 07/08/2026

No F.6/DFS/MS/EH/SZ/2026/ 677

Dated: 07/08/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s. Cuisine and Cocktail located at M-20, Second Floor, Greater Kailash-1M Block Market, New Delhi-110048, in a building comprised of Ground & 02 Upper Floors, was earlier issued FSC vide letter No- F6/MS/DFS/EH/2015/SZ/1385 dated-31/07/2015 in the name of Yo China. The premises was re-inspected by the officer concerned of this department on 27/07/2026 in the presence of Sh. Brijesh Yadav (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy Class -D "Assembly Building" (restaurant running at 2nd floor only), with effect from 07/08/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on 07/08/2026 at New Delhi by


(A.K. Malik)
Chief Fire Officer

Copy to:

1. The Commissioner MCD, Civic Centre, Minto Road, New Delhi- 110002. - to ensure the occupancy as detailed above & deviation in construction if any.
2. The authorized signatory, M/s. Cuisine and Cocktail located at M-20, Second Floor, Greater Kailash-1M Block Market, New Delhi-110048. (Online Portal ID No. 2026071509827 dated-15/07/2026).

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to nonfunctional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained firefighting staff should be available round the clock.
4. Any deviation with regard to the construction, electrical installation, lift, setback area etc., shall be verified by the concerned sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. All the means of escape such as exit, corridor, passageway, etc., shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building	M/s. Cuisine and Cocktail located at M-20, Second Floor, Greater Kailash-1M Block Market, New Delhi-110048.
2. Type of Occupancy	Group-D "Assembly Building". Comprised of Ground & 02 Upper Floors, (restaurant running at 2 nd floor).
3. Type of Case	Renewal
4. Details of previous NOC	F6/MS/DFS/EH/2015/SZ/1385 dated-31/07/2015
5. Fire Safety directives letter No	Nil
6. Date of inspection	27/07/2026
7. Name of the Inspecting Officers	Sh. Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Brijesh yadav (Manager)
9. Year of Construction	2020 (As per online application)
10. Applicant's letter No.	Online-ID No -2026071509827 dated-15/07/2026.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	4.5m	06m	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 nos.	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	0.90m	Provided	MR (old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01 nos.	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	01m each	Provided	MR (old case)
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Exhaust Fan	MR
5	Fire Extinguishers			
	• Total numbers	06 Nos ABC/CO ₂ ISI marked	08 nos.	MR
	• Types		Provided	MR
	• IS marking		Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01 nos.	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	05mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of main panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 & 180 LPM	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR


M21

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift Lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total Area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA


The fire protection systems provided in the building were checked randomly and found functional at the time of inspection.


Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/MS/DFS/EH/2015/SZ/1385 dated-31/07/2015, renewal under rule 37³⁸ of the Delhi Fire Service rules, 2010 is recommended. Accordingly, DFA is put up for approval and signatures please.


Last date of disposal-13/08/2026



 Sarabjeet Singh
 ADO (Malviya Nagar)



DO(SD) 
 5/8/24


 Ravinder Singh


 5/8/26
A.K. MALIK

br. Dr.  CFO to issue


 AD

 CFO (FZ)

 7/8/26
A.K. MALIK

DO(SD) 
 7/8/26