



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

6-9  
RECEIVED  
FIRE SERVICE  
NEW DELHI

No: F.6/DFS/MS/EH/2025/EZ/ 222

Dated: 19/07/25

To,

The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> Floor,  
Police Station, Defence Colony,  
New Delhi.

Sub: -Regarding renewal of Fire Safety Certificate in r/o M/s Culinary Craft Kitchen  
(A Unit of Binge and Brew) located at Shop No. 5, Ground Floor, Infinity  
S.K. Mall, Karkardooma, Delhi- 110092.

Sir,

This has reference to online application received through MCD portal vide ID-2025042507159, on the subject cited above. In this connection, it is to inform you that the above said assembly building was inspected by officers concerned of this department on 08/05/2025 in presence of Mr. Mihir. Following shortcoming were observed at the time of inspection.

1. Door width found 1.5 m & 0.80 m against the required width of 1.5 m each.
2. Exit signage's not provided.

In view of above, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

(Atul Garg)  
Director

Ph. 011-23414000

Pls see 222

Copy to:-

1. The owner/ occupier, M/s Culinary Craft Kitchen (A Unit of Binge and Brew) located at Shop No. 5, G.F., S.K. Infinity Mall, Karkardooma, Delhi- 110092.
2. MCD Portal ID No. 2025042507159.