



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/BP/2025/ 467

Dated: 22 / 09 / 2025

To,

The Executive Engineer (Bldg.) HQ  
Municipal Corporation of Delhi,  
9<sup>th</sup> floor, Civic Centre, Minto Road  
New Delhi 110002

**Sub: - Examination of building plans from fire safety point of view in r/o Construction of Industrial Building at Plot No. D-93 situated at Okhla Industrial Area Phase-I, New Delhi.**

Sir,

Please refer your request ID. No. 10121013 dated 11/09/2025 of online building plans, on the subject cited above. In this connection, this is to inform you that the building plans have been scrutinized by this department from fire and life safety point of view and following shortcomings are observed: -

1. Clear cut occupancy is not marked on the building plans as per clause 1.4.75 of UBBL - 2016.

In view of the above, the building plans are hereby rejected.

Yours faithfully

(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service

c