



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F.6/DFS/MS/NDZ/GH/2025/ 139

Dated: 26/03/2025

To,

The Joint Commissioner of Police (Lic.),
1st floor Police Station Defence Colony,
New Delhi

Subject:-Regarding renewal of Fire Safety Certificate in r/o M/s Daanish Residency Guest House located at 12A/19, WEA, Karol Bagh, New Delhi.

Sir,

This has reference to MCD application ID No. 2025020701563 dated 24/02/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of the above mentioned guest house from fire safety point of view in presence of Manager on dated 22/03/2025. The building comprised of basement, stilt, ground plus three upper floors. The following shortcoming was observed during the time of inspection.

1. Manufacturing/assembling electronic items in the basement.
2. Lift lobby with check door shall be required in the basement.
3. Smoke management not provided in the basement.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit..

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

2.
24/3