



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C-36



No: F.6/DFS/MS/2025/WZ/ 689

Dated: 25/08/2025

To,

The Principal,  
Daffodil Public School,  
Gali No. 5, Prem Colony,  
Bawana Road, Narela, Delhi-110040.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Daffodil Public School  
located at Gali No. 5, Prem Colony, Bawana Road, Narela, Delhi- 110040.

Sir,

This has reference to your application received through outdoor diary no. 3421 dated 07/07/2025 and e mail id dated 28/06/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 22.07.2025 to see the compliance of the requisite fire safety measures. Sh. R.P. Tyagi was present at the time of inspection.

During the course of inspection it was observed that the building comprised of Ground and Three upper floors. Your request for **renewal of FSC is rejected** as the following shortcomings were observed:-

1. First aid hose reels found provided but not functional.
2. Terrace level pump found removed.
3. Exit signage's found removed at some places.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully

  
(Virendra Singh)  
Chief Fire Officer  


Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.