

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/2025/SZ/School/756

Dated: 26/09/2025

To

The Manager,  
Daisy Dales Sr. Sec. School,  
E-331A, East of Kailash,  
New Delhi-110065

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Daisy Dales Sr. Sec. School at E-331A, East of Kailash, New Delhi-110065

Sir,

This has reference with your letter received through email dated 28/08/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said building has been carried out by the officer concerned of this department on 17/08/2025 in the presence of Mr. Sada Shiv (Manager) to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. First Aid hose reel hose found not working.
2. Terrace level fire fighting pumps found not working.
3. Overhead tank capacity 10,000 ltrs provided against the required capacity 20,000 ltrs.

In view of above Shortcomings, the application for issuance Fire Safety Certificate **is rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully,

  
25/9/2025

(VIRENDRA SINGH)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to: -

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-54.