



No.F6/DFS/MS/NDZ/2025/ 194

Dated: 22/04/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Dalit Prahari located at H – 57, Sapera Basti, Village - Gharoli, Delhi – 110096, comprised of ground floor only owned/occupied by Dalit Prahari have complied with the fire prevention and Fire Safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 12/04/2024 in the presence of Mr. Sandeep Kumar (Manager) and found that the building/premises (Mid Day Meal Kitchen) is fit for occupancy class “Industrial Building” with effect from 22/04/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010. Subject to conditions, printed below.

Issued 22/04/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. Mr. Sanjay Kumar (Secretary), Dalit Prahari at D - 39/40, Kondli Colony, Kondli, Delhi – 110096.
2. Mr. Sandeep Kumar (Manager), Dalit Prahari located at H – 57, Sapera Basti, Village- Gharoli, Delhi - 110096.
3. The Executive Engineer (Bldg), Municipal Corporation of Delhi, Plot no. 419, Patparganj Industrial Area, Delhi - 110092.

Condition for the validity of fire safety certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	M/s Dalit Prahari located at H – 57, Sapera Basti, Village - Gharoli, Delhi - 110096.		
2	Building is comprised of	Ground floors		
3	Type of occupancy	Industrial Building (Mid Day Meal Kitchen)		
4	Type of case	New Case		
5	Details of previous FSC	Nil		
6	Fire safety directives letter no.	NBC Part – IV/UBBL		
7	Date of inspection	12.04.2025		
8	Name of the inspecting officers	Yashwant Singh Meena, A.D.O / Laxmi Nagar		
9	Name of the designation of officer from the building side	Mr. Sandeep (Manager)		
10	Year of construction			
11	Applicant's letter no.	Outdoor Diary No. 14231 dated 07/03/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement NBC Part-IV/UBBL	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	6.0 meters	6.0 meters	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	N/A	N/A	N/A
	c Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	N/A	N/A	N/A
	b Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	N/A	N/A	N/A
	E Width of corridor	N/A	N/A	N/A
	F Door size	1.50 meters. x 02 nos.	2.10 meter & 1.50 meters	MR
3	Compartmentation:			
	A Fire check door	N/A	N/A	N/A
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A

5.	Fire Extinguisher:			
A	Total numbers	08 nos.	08 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	ISI Marked	ISI Marked	MR
6	First-Aid-Hose Reel:			
A	Total numbers of each floors	02 no.	02 no.	MR
B	Length of hose reel hose	30 mtrs	30 mtrs	MR
C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarming System:			
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8	MOEFA:	Required	Provided	MR
9	Public Address System:	N/A	N/A	N/A
10	Automatic Sprinkler System:			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:			
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per Branch	N/A	N/A	N/A
C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:			
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:			
1	Ground level			
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
2	Terrace Level			
A	Discharge of pump	450 LPM	450 LPM	MR
B	Head of the pump	40 mtrs	40 mtrs	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	10,000 liters	10,000 liters	MR
15	Exit Signage:		Required	Provided
16	Provision of Lifts:			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17	Standby Power Supply:		N/A	N/A
18	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	Fire Control Room:			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:		N/A	N/A

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections. The shortcomings issued vide letter no. F6/DFS/MS/INDUSTRIAL/NDZ/2025/26 dated 15.01.2025 by this department have been rectified by the management.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, it is recommended to grant Fire Safety Certificate under Rules 35 of Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer
Name : Yaswant Singh Meena
Designation: ADO /Laxmi Nagar

D.O/EAST

DFA Base

By C.F.O. (NDZ)

Approved
16/4/2025

KVP
16/4/25

C.F.O.

17/4/2025

Director

AD/LN

P.T.O