



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7  
आजादी का  
अमृत महोत्सव

No. F6/DFS/MS/NDZ/EH/2025/ 80

C-22  
Dated: - 04/03/2025

**FIRE SAFETY CERTIFICATE**

Certified that M/s. Danial Restaurant and Bar, located at 1-E/23, Ground Floor, Jhandewalan Extension, Delhi-110055, restaurant is running at Ground Floor only in a building comprised of Basement + Ground + 03 Upper Floors, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/NDZ/2022/33 dated 09/02/2022. The said premise was re-inspected by the officer concerned of this department on 26/02/2025 in the presence of Sh. A. K. Danish (Legal Advisor) and found that the premise/building have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D (Restaurant) for Ground Floor only with effect from 04/03/2025 up to 31/03/2028 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 04/03/2025 at New Delhi by.

(Atul Garg)  
Director

Tel No. 011-23414000

**Copy to:-**

1. The Joint Commissioner of Police (Lic), 1<sup>st</sup> Floor, Licensing Unit, Police Station, Defence Colony, New Delhi in r/o computer id no. 2025011500570 dated 06/02/2025
2. The Commissioner, Municipal Corporation of Delhi, Civic Centre, Minto Road, New Delhi-110002.
3. The Authorized Signatory, M/s. Danial Restaurant and Bar, 1-E/23, Ground Floor, Jhandewalan Extension, Delhi-110055.

**Following conditions for the validity of the Fire Safety Certificate: -**

1. This FSC is valid for restaurant at Ground Floor only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.



## INSPECTION REPORT

1. Name & address of the building: **M/s. Danial Restaurant and Bar** located at **1-E/23, Ground Floor, Jhandewalan Extn. Delhi-110055**
2. Type of Occupancy : **Assembly Building 'Group-D' Restaurant**
3. Type of Case : **Now Renewal.**
4. Details of previous NOC : **F6/DFS/MS/EH/NDZ/2022/33 dated 09/02/2022**  
(earlier FSC issued to M/s Carnival Restaurant and Bar)
5. Fire Safety directives Letter No. : **NBC(Part-IV)/UBBL-2016**
6. Date of inspection : **26/02/2025**
7. Name of the Inspecting Officer : **Aman Kumar Lathar, ADO (JWP)**
8. Name and designation of Officer from the building side : **Sh. A. K. Danish (Legal Advisor)**
9. Year of Construction : **2020 (As mentioned in online application)**
10. Applicant's online id no. : **2025011500570 dated 06.02.2025**

The building is comprised of Basement + Ground + 03 Upper Floors but restaurant is running at Ground Floor only.

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC(part-IV)/UBBL-2016 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	09 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	N/A	N/A	N/A
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	1.50 m x 2	1.50 m x 2	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	04 nos.	Provided	MR
	• Types	ABC & CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR

6.	First-Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	Provided	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for firefighting:			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	20,000 ltrs	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR




N-6

18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, grant of Fire Safety Certificate is recommended under rule 37 of the Delhi Fire Service Rules, 2010 under the DFS Act 2007.

Accordingly, ~~DFC~~<sup>E.T.</sup> is prepared & put up for approval please.

  
 Aman Kumar Lathar  
 ADO (JWP)

DO (CP)

2/3/25

Dy. C.F.O. (MOS)

2/3/25

C.F.O.

4/3/2025

Director

mu

uploaded  
05/03/25

Q