

c-53

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001

No. F.6/DFS/MS/WZ/GH/2025/ 106

Dated: 03/03/2025

To,

Mr. Surinder Singh,
House No.167, New Rajdhani Enclave,
New Delhi-110092.

Sub: Renewal of FSC in r/o M/s Dara Hospitality Pvt. Ltd. (Surinder Singh Dara) located at A-47, 2nd floor, Guru Nanak Pura, Delhi-110092.

Sir,

This is reference to online application no.2025012200877 dated 07.02.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **21.02.2025**, in presence of **Mr. Surinder Singh** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Smoke management /ventilation is not provided on upper floors.
2. Hose reel provided but not functional.
3. Terrace Fire pump with capacity of 450 LPM provided but not functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" /MCD Portal with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy To:-

1. MCD Portal Id- 2025012200877 dated 07.02.2025.

