

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No. F6/DFS/MS/School/WZ/2025/ 545

Dated: 24/04/2025

FIRE SAFETY CERTIFICATE

Certified that the Darbari Lal DAV Model School, located at BN-Block, Shalimar Bagh, Delhi-110088, comprised of Two Blocks (BLK-1= Basement + Ground + 02 Upper Floors & BL-2= Ground + 03 Upper Floor only, was issued FSC by this department vide letter No F6/DFS/MS/School/WZ/2021/659 dated 27/08/2021. The premises was re inspected by the officer concerned by this department on 25/03/2025 in the presence of Sh. Sanjay Gupta (Admin Officer A/C) and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The building/premises have deemed complied with fire prevention and fire safety requirements in accordance with NBC Part-IV and the building/ premises is fit for occupancy class "Educational" (Group -B) with effect from 24/04/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below.

Issued on 24/04/2025 at New Delhi.

(Atul Garg)
Director

Copy to:

1. The Director, Director of Education, Old Secretariat, Delhi-110054..
2. The Principal, Darbari Lal DAV Model School, located at BN-Block, Shalimar Bagh, Delhi-110088.. **Email Id- officedldavsb@gmail.com.**

Conditions for the validity of FSC:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction/unauthorized use of land if any.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The basement shall be used as per BBL.

INSPECTION REPORT

1.	Name & address of the building	Darbari Lal DAV Model School, located at BN-Block, Shalimar Bagh, Delhi-110088.
2.	Type of Occupancy	Educational (BL-1=Basement + Ground + 02 Upper Floors & BL-2=Ground + 03 Upper Floors)
3.	Type of Case	Renewal
4.	Details of previous NOC	F6/DFS/MS/School/WZ/2021/659 dated 27/08/2021.
5.	Fire Safety directives letter No	NBC Part-IV
6.	Date of inspection	25/03/2025
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	Sh. Sanjay Gupta (Admin Officer A/C)
9.	Year of Construction	2005 (As per previous Inspection Report dated 19/08/2021)
10.	Applicant's letter No.	Email dated 21/02/2025.

The School building comprised of Two Block (BLK-1= Basement + Ground + 02 Upper floors & BL-2= Ground + 03 Upper Floor, was already issued FSC vide letter No. F6/DFS/MS/School/WZ/2021/659 dated 27/08/2021.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 each floor	BL-1=3 & BL-2=2 Provided	MR
	• Basements	02 each floor	Provided	MR
	b. Width of staircases			
	• Upper Floors	2x1.5 m each block	Provided	MR (Old case)
	• Basements	1.5 m	BL-1=136 cm & 149 cm	MR (Old case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	Provided in each block	MR
	e. Width of Corridor	1.5m	BL-1=290 cm & BL-2=224 cm	MR
	f. Door Size	1m	110 cm	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	Required	Provided	MR
	• Upper floors	NA	Natural Ventilation	NA
5	Fire Extinguishers			
	• Total numbers	36 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

17	Re
18	
	10

[Signature]

Provision of Lifts.			
• Pressurization of Lift Shaft	NA	NA	NA
• Pressurization of Lift lobby	NA	NA	NA
• Communication In lift Car	Required	Provided	MR
• Fireman's Grounding Switch	Required	Provided	MR
• Lift Signage	Required	Provided	MR
17 Standby power supply	NA	NA	NA
18 Refuge Area.			
➤ Total Area	NA	NA	NA
➤ Location	NA	NA	NA
19 Fire Control Room			
• Detector System Panel	NA	NA	NA
• Flow Switch Panel	NA	NA	NA
• PA System Panel	NA	NA	NA
• Battery backup	NA	NA	NA
• Building Floor Plans	NA	NA	NA
20 Special Fire Protection Systems for Protection of special Risks, if any:	NA	ABC type Fire Ext. Provided near electrical panel	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/School/WZ/2021/659 dated 27/08/2021, renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

ADDO/MN
10/4/2025

ADDO (P.O.)/MN

ADDO
10/04/2025

Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)

ADDO
03/04/2025

CFD/Kings
14/4/2025

Director
14/4/25

Discharge
14/4/25

Sir P-7 is put up for your
Kind personal & Signature p/s!!
21/4/2025

636 WD
31/4/2025