



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आजादी का
अमृत महोत्सव


o. F6/DFS/MS/GH/NDZ/2025/ 391

Dated:- 03/06/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Darpan Palace Guest House, located at 7923/2, Arakashan Road, Pahar Ganj, New Delhi-110055, comprised of Ground + 03 Upper Floors, ground floor (reception + 01 room), 1st to 3rd floor (06 guest rooms at each floor), Total 19 guest rooms, was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/GH/2022/NDZ/347 dated 14/07/2022. The said premise was re-inspected by the officer concerned of this department on 21/05/2025 in the presence of Sh. Sonu (Caretaker) and found that the said guest house building having given an affidavit dated 25/11/2019 regarding not to use any floor above 3rd floor, has deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class Residential, (Sub Division A-1) ground floor (reception + 01 rooms) 1st to 3rd floor (06 guest rooms at each floor) Total 19 guest rooms upto 3rd floor only, with effect from 03/06/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 printed below.

Issued on 03/06/2025 at New Delhi by


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, Civic Centre, Minto Road, New Delhi-110002:- in r/o computer id no. 2025050507857 dated 05/05/2025, also to ensure occupancy as detailed above and deviation, if any.
2. The Joint Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi
3. The Authorized Signatory, M/s Darpan Palace Guest House, 7923/2, Arakashan Road, Pahar Ganj, New Delhi-110055.

Conditions for the validity of fire safety certificate:-

1. The FSC shall be stand null and void if numbers of lodgers are found more than 10 at any one floor.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
10. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1. Name & address of the building : **M/s Darpan Palace Guest House**, located at **7923/2, Arakashan Road, Pahar Ganj, New Delhi-110055**
2. Type of Occupancy : Residential Sub Division A-1,
Ground + 03 Upper Floors (Total 19 Guest Rooms) ground floor (reception + 01 guest room) 1st to 3rd floor (06 guest rooms at each floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/GH/ 2022/ NDZ/347 dated 14/07/2022
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 21/05/2025
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer from the building side : Sh. Sonu (Caretaker)
9. Year of Construction : 1989
10. Applicant's online application no. : 2025050507857 dated 05/05/2025

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none">Road width	NA	01 m	NA
	<ul style="list-style-type: none">Gate width	NA	NA	NA
	<ul style="list-style-type: none">Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none">Upper floors	01 no.	Provided	MR
	<ul style="list-style-type: none">Basements	NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none">Upper floors	0.80 m	1.25 m	MR
	<ul style="list-style-type: none">Basements	NA	NA	NA
	c. Protection of exits			
	<ul style="list-style-type: none">Fire check door	NA	NA	NA
	<ul style="list-style-type: none">Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	1.0 m	Provided	MR
	f. Door Size	1.0 m	Provided	MR
3.	Compartmentation			
	<ul style="list-style-type: none">Fire check door	NA	NA	NA
	<ul style="list-style-type: none">Sealing of electrical shafts	NA	NA	NA
	<ul style="list-style-type: none">Fire Rating of shaft door	NA	NA	NA
	<ul style="list-style-type: none">Water Curtain	NA	NA	NA
	<ul style="list-style-type: none">Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none">Basements	NA	NA	NA
	<ul style="list-style-type: none">Upper floors	Required	Natural /Exhaust Fan	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none">Total numbers	10 nos.	Provided	MR
	<ul style="list-style-type: none">Types	ABC & CO ₂	Provided	MR
	<ul style="list-style-type: none">IS marking	Required	Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	01 no.	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors (CO Type)	Required	Provided	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Each Floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			NA
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			NA
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			NA
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	Required	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5000 ltrs.	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR

18.	Refuge Area	NA	NA	NA
	➤ Total area	NA	NA	NA
	➤ Location			
19.	Fire control room	NA	NA	NA
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no. F6/DFS/MS/GH/ 2022/ NDZ/347 dated 14/07/2022, renewal under rule 37 of the Delhi Fire Service Rule 2010, is recommended.

Accordingly, DFA is put up for approval & signature please.

Printed
23/05/25
Aman Kumar Lathar
ADO (JWP)

DO/CO

DO
26/5/25

Dy. C.F.O. (MS)

KVP
28/05/25

C.F.O.
30/5/2025

DO/CO

DO
26

ADO (JWP)

F.i. letter is put-up for your signature pl.

CFO
21/6/2025

Printed
22/06/25

MS CFI

U. H. D. S.
03/07/25