



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2025/School/ 138

Dated: 11 / 02 / 2025

FIRE SAFETY CERTIFICATE

Certified that the Darshan Public School located at Plot No. 05, Khasra No- 38/14, Gali No-8, A Block, Amrit Vihar, Burari, Delhi-110084 comprised of ground & 03 upper floors but (school is running at ground & first floor only) owned/ occupied by Darshan Public School was issued Fire Safety Certificated vide this office letter no. F6/DFS/MS/2017/School/WZ/1048 dated 17/07/2017. The premise was inspected by the officer concerned of this department on 28.01.2025 in the presence of Sh. Jamidar Singh (Manager) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "Group B Educational" with effect from11/02/2025 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on11/02/2025 at New Delhi

(Atul Garg)
 Director
 Ph:-011-23414000

Copy to:-

1. The Deputy Director of Education, GNCT of Delhi, Zone-VII, District North Lucknow Road, Timarpur, Delhi – 110054.
2. The Principal, Darshan Public School located at Plot No. 05, Khasra No- 38/14, Gali No-8, A Block, Amrit Vihar, Burari, Delhi-110084.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".
8. This Fire Safety Certificate is valid only for ground & first floor. If any additional construction temporary or permanent is made in future, the Fire Safety Certificate will be treated as null & void.

INSPECTION REPORT

1. Name & address of the building : Darshan Public School at Plot No. 05, Kh. No- 38/14, Gali No-8, A block Amrit Vihar, Burari, Delhi-110084.
2. Composition of building : Ground & 03 upper floor, But (school is running at ground & first floor Only), 2nd & 3rd floor is being used for residential purpose only.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2017/School/WZ/1048 dated 17/07/2017
6. Fire Safety directives letter No : Nil
7. Date of inspection : 28.01.2025
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Sh. Jamidar Singh (Manager)
10. Year of Construction : 2004, 2006, 2015 & 2021
11. Applicant's letter No. : Online E-mail dated 10.01.2024

| | Minimum Standards on fire prevention and fire safety U/R 33 | Requirements as per Rule 35 (6) | Provided at site | Remarks MR/NMR |
|---|---|---------------------------------|----------------------|----------------|
| 1 | Access to building | | | |
| | • Road width | 06m | 06m | MR |
| | • Gate width | Directly Accessible | Directly Accessible | MR |
| | • Width of internal road | NA | NA | NA |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | 02 | 03 | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper Floors | 1.50m | 1.50m, 1.30m & 1.20m | MR |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | NA | 03 | NA |
| | e. Width of Corridor | NA | NA | NA |
| | f. Door Size | 01m | 01m | MR |
| 3 | Compartmentation. | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4 | Smoke Management System. | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | NA | NA | NA |
| 5 | Fire Extinguishers | | | |
| | • Total numbers | 08nos | 10nos | MR |
| | • Types | ABC/CO2 | ABC-10 | MR |
| | | ISI Marked | Provided | MR |

| | | | | |
|----|--|-----|----------|-----|
| | • ISI marking | | | |
| 6 | First-Aid Hose Reels. | | | |
| | • Total numbers on each floor | NA | 01 | NA |
| | • Length of hose reel hose | NA | 30m | NA |
| | • Nozzle diameter | NA | 5mm | NA |
| 7 | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8 | MOEFA | NA | NA | NA |
| 9 | Public Address System. | NA | NA | NA |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11 | Internal Hydrants | | | |
| | • Size of riser/down-comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main Pump | N/A | N/A | N/A |
| | ➤ Head of Main pump | N/A | N/A | N/A |
| | ➤ Number of main pumps | N/A | N/A | N/A |
| | ➤ Jockey Pump out put | N/A | N/A | N/A |
| | ➤ Jockey pump head | N/A | N/A | N/A |
| | ➤ Standby Pump out put | N/A | N/A | N/A |
| | ➤ Standby Pump Head | N/A | N/A | N/A |
| | ➤ Auto Starting/ Manual stopping | N/A | N/A | N/A |
| | ➤ Pump House Access | N/A | N/A | N/A |
| | • Terrace level | | | |
| | ➤ Discharge of pump | NA | 450 LPM | NA |
| | ➤ Head of the pump | NA | 40m | NA |
| | ➤ Power Supply | NA | Provided | NA |
| | ➤ Auto Starting of pump | NA | Provided | NA |
| 14 | Captive Water Storage for fire fighting. | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw-off connection | NA | NA | NA |
| | | NA | NA | NA |

N/2

| | | | | |
|----|--|-----|-----|-----|
| 15 | Exit Signage. | NA | NA | NA |
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | N/A | N/A | N/A |
| | • Pressurization of Lift lobby | N/A | N/A | N/A |
| | • Communication In lift Car | N/A | N/A | N/A |
| | • Fireman's Grounding Switch | N/A | N/A | N/A |
| | • Lift Signage | N/A | N/A | N/A |
| 17 | Standby power supply | NA | NA | NA |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | N/A | N/A | N/A |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | N/A | N/A |
| | • Batter backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/2017/School/WZ/1048 dated 17/07/2017.

Signature of the Inspecting Officer
 Name :- C.L. Meena
 Designation:- ADO/RN

DO (NW)

04/02/2025

dy cfo (wz) - MR

cto/ 6/21/2025

Director

7/2/25

Na/en

conf - - P.T.O.

3.56.442...
 dated... 6/2/2025