



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/4
आज़ादी का
अमृत महोत्सव

Dated: 11 /04/2026

No. F6/DFS/MS/EH/WZ/2026/ 313

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Center, New Delhi – 110002.

Subject: - Regarding renewal of Fire Safety Certificate in r/o M/s Daryaganj (A unit of Saaj Foods and Hospitality Pvt. Ltd.) located at unit No.11, Second floor, Pacific Mall, Khayala, Suhash Nagar Metro Station, Delhi.


Sir,

This has a reference to MCD application No. 2026031202774 dated 12/03/2026, on the subject cited above. In this connection, this is to inform you that the above-mentioned premises was visited by the officer concerned of this department on dated 04/04/2026 in the presence of Mr. Radhy Shyam Sharma (Fire & Safety Manager) to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observation: -

1. Alternate exit of width 0.75 mtr. provided against the requirement of 1.5 mtr.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


10/04/26
(S.K. Dua)
Dy. Chief Fire Officer
Delhi Fire Service
o/c