



C45

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/School/NDZ/2025/100

Dated:-31.01.2025

FIRE SAFETY CERTIFICATE

Certified that the **DAV Public School located at West Patel Nagar New Delhi-110008** Comprises of two block i.e Ground +1 & G+1 & Temp. Shed at 2nd floor (not in use for any purpose as per undertaking dated 15.01.2025). The FSC was earlier granted by this department vide letter No. **F6/DFS/MS/School/SZ/2021/653 dated 26/08/2021**. Now, the premises was re-inspected by the officer concerned of this department on 15-01-2025 in the presence of Ms. Rashmi Gupta (Principal) and found that the said school building except temporary shed at second floor has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class **Group B "Educational Building" (Sub-Div. B-I) , Ground & first floor only** with effect from**31.01.2025** for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on**31/01/2025** at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Commissioner , MCD Civic Centre New Delhi . to ensure in deviation in construction if any.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
3. The Principal, DAV Public School located at West Patel Nagar New Delhi-110008.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. This FSC is valid only for block ground and first floor only and temporary shed at second floor shall be closed.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area , occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

N/27
INSPECTION REPORT

1. Name & address of the building:- DAV Public School located at West Patel Nagar New Delhi-110008.
2. Type of occupancy:- Educational Building, Gr. + 1 Upper floors and Gr. +1 + **temporary shed at second floor (not in use as per under taking 15.01.2025)**
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/School/SZ/2021/653 dated 26/08/2021.
5. Fire safety directives No.- N/A
6. Date of inspection:- 15/01/25
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer
From the building side:- Ms. Rashmi Gupta (Principal)
Old
9. Year of construction:- Old
10. Applicant's letter No:- letter no. DAV/PS/WAV/2024-25/132 dated 15.01.2025.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	requirements as per previous FSC	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06	06 mtr.	MR
	2) Gate width	4.5 mtr.	Provided	MR
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	03	03	MR
	2. Basements	NA	NA	NA
	B. Width of staircase			
	1. Upper floors	1.5 mtr. of 01 or 2 of any width	1.5m , 1.2 & 1m	MR
	2. Basements	NA	NA	NA
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
		N/A	N/A	N/A
	E. Width of corridor			
		150 cms	Provided	MR
	F. Door size			
		100 cm	Provided	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	10 Nos.	Provided	MR

N/28

	2) Types	ABC & CO2	ABC, CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank	N/A	N/A	N/A

N/29

	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: DCP, CO ₂			MR

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules if approved, we may renew the FSC issued vide letter No. F6/DFS/MS/School/SZ/2021/653 dated 26/08/2021, under Rule 35(6) of the Delhi Fire Service rules 2010.

Signature of the Inspecting Officer

Name: - Sh. Ravinder Singh
Designation: ADO (CC)

9/2/25
28/1/25

CFs/ 28/01/2025
Director

Boys