



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI **HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/2025/School/ 865

Dated: 03/12/2025

To,

The Principal, DAV Public School, R.B.E. Paschim Vihar, New Delhi-110063.

Sub: Issue of FSC in r/o DAV Public School, located at R.B.E. Paschim Vihar, New Delhi-110063.

Sir.

Kindly refer to online e-mail dated 04.11.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 15.11.2025, in presence of Mr. Akash to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Fire extinguisher are found removed.

2. First Aid Hose reel provided but not functional.

3. Manually operated electric fire alarm system provided but not functional.

4. Terrace Fire pump with capacity of 2200 LPM provided but not functional.

5. 2000 ltrs Over Head water captive tank provided against the required capacity of 2500 ltrs

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under: http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http:// www.delhi.gov.in/wps/wcm/connect/doit fire/FIRE/Home/Forms

Yours faithfully

(S. K. Dua)

02/12/25

Dy. Chief Fire Officer (WZ) Delhi Fire Service

