



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001



No. F6/DFS/MS/School/NDZ/2025/ 243

Dated: 12/03/2025

FIRE SAFETY CERTIFICATE

Certified that the **D.A.V Public School** at Pocket - C, LIG DDA Flats, East of Loni Road, Delhi - 110093, building comprised of **Ground plus three upper floors, (School running at Ground + Two upper floors only)** owned / occupied by **D.A.V Public School**, was issued FSC vide letter No. F6/DFS/MS/School/2021/NDZ/1084 dated 28/12/2021. The School building was re-inspected by the officer concerned of this department on 04.03.2025 in presence of Mrs. Sameeksha Sharma (Principal) and found that all the said school have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the school is fit for occupancy class Group- B "**Educational Building**" with effect from 12/03/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 12/03/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

D/C DELHI FIRE SERVICE

Copy to:-

1. The Principal, D.A.V Public School, Pocket-C, LIG DDA Flats, East of Loni Road, Delhi-110093.
2. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi -110053.

Conditions for the validity of Fire Safety Certificate

1. **Fire Safety Certificate is valid for ground plus two upper floors only.**
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
7. At the time of inspection third floor not being used & found closed.
8. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
9. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	D.A.V. Public School, Pocket-C, LIG DDA Flats, East of Loni Road, Delhi-110093.		
2	Building is comprised of	Ground + Three Upper Floors (School running at Ground + Two upper floors only)		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2021/NDZ/1084 dated 28/12/2021		
6	Fire safety directives letter no.	NBC Part - IV		
7	Date of inspection	04/03/2024		
8	Name of the inspecting officers	Yashwant Singh Meena ADO, Laxmi Nagar		
9	Name of the designation of officer from the building side	Mrs. Sameeksha Sharma (Principal)		
10	Year of construction	2001		
11	Applicant's letter no.	Email dated 15/01/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Circular Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	6.0 meters.	6.0 meters.	MR
	B Gate width	4.50 meters.	5.0 meters.	MR
	C Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	02 nos.	02 nos.	MR
	b Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.5 mtr.	1.5 mtr. & 1.15 mtr.	MR
	b Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	01 no.	02 no.	MR
	E Width of corridor	1.50 mtrs.	1.70 mtrs.	MR
	F Door size	1.0 mtr.	1.0 mtr.	MR
3	Compartmentation:			
	A Fire check door	N/A	N/A	N/A
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A

5.	Fire Extinguisher:				
	A	Total numbers	12 nos.	20 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI Marked	Provided	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	01 no.	02 no.	MR
	B	Length of hose reel hose	30 mtr.	30 mtr.	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:		N/A	N/A	N/A
9	Public Address System:		N/A	N/A	N/A
10	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	450 LPM	450 LPM	MR
	B	Head of the pump	40 m	40 m	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

N/27

D.A.V Public School, Pocket-C, LIG DDA Flats, East of Loni Road, Delhi-110093


14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	N/A	N/A
	B	Draw-off connection	N/A	N/A
	C	Fire service inlet	N/A	N/A
	D	Access to tank	N/A	N/A
	E	Overhead tank capacity	10,000 liters.	10,000 liters.
15	Exit Signage:		Required	Provided
16	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	N/A	N/A
17	Standby Power Supply:		N/A	N/A
18	Refuge Area:			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19	Fire Control Room:			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:		N/A	N/A

NOTE: - At the time of inspection third floor not in use. (Undertaking enclosed)

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/School/2021/NDZ/1084 dated 28/12/2021, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended to be renewed.

No file is pending with me before disposal of this case.


5/3/2025

Signature of the Inspecting Officer

Name: - Yashwant Singh Meena

Designation: - ADO/Laxmi Nagar

D.O/EAST / on leave.

DCFO/NDZ
C.F.O.
7/3/2025
Director
P.T.D

Ad/LA

P.T.D