

c/s

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/2025/EH/SZ/96

Dated: 25 / 02 / 2025

To

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor PS Defence Colony,
New Delhi 110049.

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Dawn De Cafe located at H-15, old No H-5-6, Village Shakarpur Khas Laxmi Nagar, Shahdara Delhi 110092

Sir,

This is in reference to with **MCD Portal ID 2025010300080 dated 28/01/2025** on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 22.02.2025 in the presence of Mrs. Sharda Gupta to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. There is one staircase having width of 1.35 mtr against the required two staircase having width of 1.50 mtr each.
2. There is one Exit door having width of 1.20 mtr against the required two exit doors having width of 1.50 mtr each.
3. First Aid Hose reel not provided.
4. The MOEFA system provided not working.
5. The Internal Hydrant not provided.
6. Terrace level Fire Pump capacity of 450 LPM not provided.
7. Overhead tank capacity 20,000 ltrs not provided.
8. Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Atul Garg