



C 22
26/11/25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/NDZ/1343

Dated: 26/11/2025

FIRE SAFETY CERTIFICATE

Certified that the Dayanand Model Sr. Sec. School located at B-Block, Vivek Vihar, Delhi-110095, comprised of Ground plus two upper floors, owned/occupied by Dayanand Model Sr. Sec. School was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2022/NDZ/774 dated 22/07/2022 for G+1. The premise was inspected by the officer concerned of this department on dated 14/11/2025 in the presence of Sh. Rahul (Admin. Staff) and observed that the said premises have complied with the fire prevention and fire safety requirement in accordance with rules 33 of Delhi Fire Service Rules 2010 and that the premises/building is fit for occupancy class "Educational" (Group-B) as above, with effect from 26/11/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/11/2025 at New Delhi by


(Dr. S. K. TOMAR)
DY. CHIEF FIRE OFFICER (NDZ)
DELHI FIRE SERVICE

Copy to: -

1. The Manager, Dayanand Model Sr. Sec. School, B-Block, Vivek Vihar, Delhi-110095
2. The Dy. Director of Education, B-Block, Vivek Vihar, New Delhi-110095

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT				
1.	Name & address of the building	Dayanand Model Sr. Sec. School, B-Block, Vivek Vihar, Delhi-110095		
2.	Type of Occupancy	Educational Group-B (School)		
3.	Building Comprised of	Ground plus two upper floors		
4.	Type of Case	Addition/Alteration		
5.	Details of previous NOC No.	F.6/DFS/MS/School/2022/NDZ/774, Dated 22/07/2022 (G+1)		
6.	Fire Safety directives Letter No.	NBC Part IV		
7.	Date of inspection	14/11/2025		
8.	Name of the Inspecting Officer	Deepak Kumar, ADO (Tahirpur)		
9.	Name and designation of Officer from the building side	Mr. Rahul (Admin. Staff)		
10.	Year of Construction	1980-1995		
11.	Applicant's letter No.	Email:- dayanandmodel@yahoo.com dated 07/11/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Requirements/ NBC Part IV	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	06 mtr	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03 Nos	04 Nos	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr	1.50m, 1.50m, 1.50m & 1.17m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	02 Nos	02 Nos	MR
	e. Width of Corridor	1.5 mtr	2.30 mtr	MR
	f. Door Size	01 mtr	01 m & 1.20 m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	18 Nos	20 Nos	MR
	• Types	ABC/CO ₂	ABC & CO ₂	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	03 nos.	03 nos.	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR


7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 Ltrs.	10,000 Ltrs.	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19.	Fire Control Room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view of the Substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/2022/NDZ/774 dated 22/07/2022 (G+1), It is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Accordingly, DFA is put up for approval and signature please.


Signature of the Inspecting Officer
Name : Deepak Kumar
Designation : ADO (Tahirpur)

DO (ED)

Earlier FSC is issued for G+1 upper floor, now G+2 upper floors. Pl. clarify.


19/11/25

ADO (Tahirpur)

Sir, The Applicant has submitted the sanctioned building plan from DDA. Accordingly the case is put up for G+2 upper floor. Submitted pl.

DO (ED)


20/11/25


20/11/25

Principal Director


21/11/25

Principal Director

Day. case to



21/11/25