



c 76

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/EH/2025/SW/61

Dated: 19/02/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s De Forbidden Restaurant (A Unit of De Forbidden Entertainment & Hospitality P. Ltd.) running at 2nd floor in a building comprised of two tier basement, ground floor plus ten upper floors located at 108 to 112A, Westend Mall, District Centre, Janakpuri, New Delhi-110058, owned/occupied by M/s De Forbidden Restaurant A Unit of De Forbidden Entertainment & Hospitality P. Ltd. was issued FSC by this department vide letter No. F.6/DFS/MS/EH/ 2021/SZ/360 dated 10/12/2021. The premise was re-inspected by the officer concerned of this department on 17/02/2025 in the presence of Mr. Akash Sehrawat (Owner) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and observed that the premises (108 to 112A, 2nd floor only) is fit for occupancy Class "Assembly, Group-D" (restaurant at 2nd floor) with effect from 19/02/2025 and valid up to 31/03/2028 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....19/02/2025.....at New Delhi by

(ATUL GARG)
DIRECTOR

dc 2 DELHI FIRE SERVICE

To:-

1. The Joint. Commissioner (Lic.), 1st floor Police Station Defence Colony, New Delhi
MCD ID No. 2025020301394
2. Mr. Akash Sehrawat, De Forbidden Restaurant (A Unit of De Forbidden Entertainment & Hospitality P. Ltd.) at 108 to 112A, 2nd floor, Westend Mall, District Centre, Janakpuri, New Delhi-110058.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The basement shall be used as per the provisions of BBL/NBC Part-IV.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : M/s De Forbidden Restaurant & Discotheque (a Unit of De Forbidden Entertainment & Hospitality P. Ltd), 2nd floor, 108 to 112, Westend Mall, District Centre, Janakpuri,, New Delhi -110058
2. Building is comprised of : 02 tier Basement, Ground floor plus ten upper Floors (Restaurant is running at Second floor only)
3. Type of Occupancy : Group D (Assembly Building)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/EH/ 2021/SZ/360 dated 10/12/2021
6. Fire Safety directive letter No : N/A
7. Date of Inspection : 17/02/2025
8. Name of the Inspecting officers : ADO (Shd.) Deepak Kumar
9. Name and designation of Officer from the building side : Mr. Akash Sehrawat
10. Applicant's letter No : 2025020301394 dated 04/02/2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Requirement/ Existing Fire Protection	Provided at Site	Remarks MR/NMR
01	Access to building.			
	• Road width	09 mtrs.	18 mtrs.	MR
	• Gate width	4.5 mtrs.	05 mtrs.	MR
	• Width of internal road	06 mtrs.	Provided	MR
02	Number, Width, Type and Arrangement of Exits. Common with westend mall building			
	a. Number of Staircases			
	• Upper Floor	05 nos.	05 nos.	MR
	• Basement	08 nos. & 01 ramp	08 nos. & 01 ramp	MR
	B. Width of Staircases			
	• Upper Floor	1.25 mtrs.	1.47, 1.48, 1.26, 1.26 & 1.22 mtrs.	MR (old case)
	• Basement	1.50/1.25 mtrs.	1.50, 1.44, 1.28, 0.93, 1.25, 1.25, 1.25 & 1.25 mtrs.	MR (old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	04 nos.	MR
	e. Width of Corridor	N/A	Opening in hall	N/A
	f. Door Size	02 mtrs.	2.10, 1.07 & 0.64 mtrs.	MR
03	Compartmentation. (Restaurant is at SF only)			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire rating of shaft door	Required	01 Hrs.	MR
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	Required	Provided	MR
04	Smoke Management System. Common with westend mall building			
	• Basement	Required	Mechanical Ventilation system	MR
	• Upper floor	Required	Natural ventilation provided	MR
05.	Fire Extinguishers.			
	• Total numbers	08 nos.	08 nos.	MR
	• types	ABC/CO ₂	ABC/CO ₂	MR
	• IS marking	Required	Provided	MR


06	First-aid-Hose Reels.	Common with westend mall building		
	Total numbers on each floor	02 No.	02 No.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.	(Restaurant is at SF only)		
	• Type of detectors CO	Required	Provided	MR
	• Location of main panel	Required	Near main gate	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Required	In hall/exits	N/A
08	MOEFA	Required	Provided	MR
09	Public address System.	Required	Provided	MR
10	Automatic Sprinkler System.	(Restaurant is at SF only)		
	• Basement	Required	Provided	MR
	• upper floor	Required	Provided	MR
	• sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants	(Restaurant is at SF only)		
	• size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	04 nos.	Provided	MR
	• Hose Box	04 nos.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	04 nos.	Provided	MR
	• Hose Box	04 nos.	Provided	MR
13	Pumping Arrangements.	Common with westend mall building		
	• Ground Level			
	➤ Discharge of main Pump	4500 LPM	Provided	MR
	➤ Head of Main Pump	70 m	Provided	MR
	➤ Number of main pumps	02 nos	Provided	MR
	➤ Jockey pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	70 m	Provided	MR
	➤ Standby pump out put	4500 LPM	Provided	MR
	➤ Standby pump Head	70 m	Provided	MR
	➤ Auto Starting /Manual stopping	Both	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	2,00,000 ltrs	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	30,000 ltrs.	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	Required	Provided	MR
	• Pressurization of Lift lobby	Required	Provided	MR
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR

N/29.

17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	<input type="checkbox"/> Total area	N/A	N/A	N/A
	<input type="checkbox"/> Location	N/A	N/A	N/A
19	Fire Control Room			
	<input type="checkbox"/> Detector system panel	N/A	N/A	N/A
	<input type="checkbox"/> Flow switch panel	N/A	N/A	N/A
	<input type="checkbox"/> PA system panel	N/A	N/A	N/A
	<input type="checkbox"/> Battery backup	N/A	N/A	N/A
	<input type="checkbox"/> Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A		N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection. The Mall FSC already issued vide letter no. F.6/DFS/MS/Mercantile/SZ/2025/19 dated 09/01/2025.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, the FSC issued vide letter no. F.6/DFS/MS/EH/ 2021/SZ/360 dated 10/12/2021 renewal under 35 of the Delhi Fire Service rules 2010, is recommended.


 Signature of the Inspecting Officer
 Name : Deepak Kumar
 Designation : ADO (Shd)

DO(SW).


17/2/25

CFD
18/2/2025

Director
18/2/25

AMY/SR

Please upload online ncd Part 2 & keep in record. Pl.


 18/02/2025

ms(cell)

Uploded
21/2/25