



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/GH/2025/SZ/ 47

Dated: 28/01/2025

To

The Joint Commissioner of Police (Lic.),
1st Floor, P.S. Defense Colony
New Delhi-110049

Sub: Inspection report in r/o M/s De Holiday International Guest House located at 2218, Raj Guru Road, Chuna Mandi, Pahar Ganj, New Delhi-110055

Sir,

This has reference to online application No. 2024122718448 dated 15/01/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on dated 15/01/2025 from fire safety point of view, in the presence of Sh. Tushar Sikka (Owner) of the guest house. During course of inspection, the shortcomings observed are as below.

1. Single staircase provided found obstructed with wooden racks at 4th floor.
2. Hose-reel hose provided found non-functional.
3. Kitchen running at terrace and waste material stored.
4. Access to inspect over-head water storage not provided.

In view of the above, the application for renewal of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Proprietor M/s De Holiday International Guest House located at 2218, Raj Guru Road, Chuna Mandi, Pahar Ganj, New Delhi-110055