



C-33



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No F.6/DFS/MS/2025/School/WZ/ 443

Dated: 03/04/2025

FIRE SAFETY CERTIFICATE

Certified that **Deep Chand Public School, Begumpur, (Opp. Rohini Sec-22, Delhi-110085)** comprised of **Ground + One upper floor** owned/occupied by **Deep Chand Public School** has already been issued fire safety certificate vide letter no. **F.6/DFS/MS/2021/School/WZ/850** Dated **13.10.2021**. The premises was re-inspected by the officer from this department on dated **24.03.2025** in the presence of **Sh. Kapil** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deem complied with the requirements of **Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398** dated **01/03/2011** issued by Director of Education and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from 03/04/2025 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 03/04/2025 at New Delhi by

(Atul Garg)
DIRECTOR
Ph: 011-23414000

Copy to:

1. The Principal, Deep Chand Public School, Begumpur, (Opp. Rohini Sec-22, Delhi-110085).
2. The Director of Education, Old Secretariat, Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Deep Chand Public School, Begumpur, (Opp. Rohini Sec-22) Delhi-110085
2. Type of Occupancy : Educational
3. Type of Case : Renewal (**Ground + 01 upper floor**)
4. Details of previous NOC : F.6/DFS/MS/2021/School/WZ/850 Dated 13.10.2021
5. Fire Safety directives letter No : Dir of Edu. Cir 01/03/2011
6. Date of inspection : 24.03.2025
7. Name of the Inspecting Officers : A.K.Sharma ADO (Rohini)
8. Name and designation of officers from the building side : Sh. Kapil
9. Year of Construction : 2009
10. Applicant's letter No. : OD No.212977 dated 27.02.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01nos.	02nos.	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floors	1.50 mtr	0.85 mtr up to 1 st floor & 1.40 mtr up to roof	MR
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	e. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	g. Width of Corridor	-NA-	-NA-	-NA-
	h. Door Size	1.00 mtr	1.00 mtr	MR
3	Compartmentation.			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4	Smoke Management System.			
	• Basements	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5	Fire Extinguishers			
	• Total numbers	07 ABC	08 nos.	MR
	• Types		ABC-8	MR
	• IS marking	ISI marked	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	One	Provided	MR

	<ul style="list-style-type: none"> Length of hose reel hose Nozzle diameter 	30 m 5 mm	Provided Provided	MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
8	MOEFA	-NA-	-NA-	-NA-
9	Public Address System.	-NA-	-NA-	-NA-
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	-NA- -NA-	-NA- -NA-	-NA- -NA-
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- 450 LPM 40 M -NA- -NA-	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- Provided Provided -NA- -NA-	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- MR MR -NA- -NA-
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	-NA- -NA- -NA- -NA- 5,000 ltrs NA	-NA- -NA- -NA- -NA- Provided NA	-NA- -NA- -NA- -NA- MR NA
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car 	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-

	• Fireman's Grounding Switch	-NA-	-NA-	-NA-
	• Lift Signage	-NA-	-NA-	-NA-
17	Standby power supply	-NA-	-NA-	-NA-
18	Refuge Area.			
	➤ Total Area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-
19	Fire Control Room			
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA System Panel	-NA-	-NA-	-NA-
	• Batter backup	-NA-	-NA-	-NA-
	• Building Floor Plans	-NA-	-NA-	-NA-
20	Special Fire Protection Systems for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, the FSC issued vide letter no. **F.6/DFS/MS/2021/School/WZ/850 Dated 13.10.2021** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO (NW)

26/03/2025
by cfo (wz)

27/3

DCFO/ 1107-NW2

Date: 27/03/25

CFD

29/31/2025
Director

Any AKS/for

For letter to put up for renewal
perusal and signature please.

Director

24/4/25