



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

21/9  
आजादी का  
अमृत महोत्सव

No. F6/DFS/MS/School/2025/NDZ/ 750

Dated: 23/09/2025

To,

The Principal,  
Deepak Public School,  
A-293, 25 FT. Road, Rama Garden,  
Karwal Nagar, Delhi-110094.

Subject: - Regarding issuance of Fire Safety Certificate in r/o Deepak Public School located at A-293, 25 FT. Road, Rama Garden, Karawal Nagar, Delhi-110094.

Sir,

Please refer to your outdoor dairy No.5165 dated 22/08/2025 on the subject cited above. In this connection, it is to inform you that the site was visited by officer concerned of this department on dated 13/09/2025 in the presence of Mr. Jile Singh (Manager) and observed that the shortcoming has still not complied with as issued by this department vide letter no. F6/DFS/MS/2022/NDZ/462 dated 04/08/2022 (copy overleaf).

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully,

Enclose as above

11/9/2025

VIRENDRA SINGH  
CHIEF FIRE OFFICER  
o/c DELHI FIRE SERVICE

Copy to: -

1. The Director of Education, MCD Civic Centre, Jawahar Lal Nehru Marg, New Delhi-110002.

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/2022/NDZ/ 462

Dated: 4/8/2022

To

The Manager,  
Nav Deepak Public School, A-293,  
Street No.-2, Rama Garden, Karawal Nagar, Delhi-110090.

**Sub.:- Inspection Report in r/o Nav Deepak Public School, A-293, Street No.-2, Rama Garden, Karawal Nagar, Delhi-110090.**

Sir,

With reference to your letter No Nil dated 20/05/2022 & outdoor diary no. 1865 dated 26/05/2022 on the subject noted above. In this connection it is to inform you that the said building premises was inspected by the officer concerned of this department on 20.07.2022 in the presence of Sh. Zile Singh.

During the course of inspection it was observed that the building premises is comprised of Ground & 1st Floor Only (Earlier school was Ground Floor only).


**However following shortcoming was observed during the time of inspection:-**

1. One staircase of width 1.30mtr provided against requirement of 2 staircases of with 1.50mtr each.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR.

ok 

Copy to :-

1. Director of Education, Old Secretariat, Civil Lines, Delhi-110054.