



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C/15
2025

No. F.6/DFS/MS/School/2025/WZ/554

Dated: 01/07/2025

To,

The Principal,
Deepjyoti Public School,
Sohti Road, Qutabgarh,
Delhi-110039.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Deepjyoti Public School located at Sohti Road, Qutabgarh, Delhi- 110039.

Sir,

This has reference to your email id dated 27.05.2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 21.06.2025 to see the compliance of the requisite fire safety measures. Sh. Azad Singh Lamba was present at the time of inspection.

During the course of inspection it was observed that previously this department had issued FSC vide letter no. F6/DFS/MS/2018/School/WZ/2039 dated 06/09/2018 for a building comprised of Ground and first floor. Now the school management had added one more floors in the existing building of ground and first floor and now the school building is comprised of ground plus two upper floors. Your request for issuance of FSC is rejected due to the following shortcomings:-

1. There is only one staircase reaches up to terrace against the requirement of both the staircases reaches up to terrace.
2. First aid hose reels found not provided.
3. Terrace level pump of 450 lpm discharge capacity found not provided.
4. Overhead tank of 10,000 ltrs capacity found not provided.
5. Exit signage's are not provided.
6. Building plan on a scale of 1:100 duly signed by registered architect and the owner not provided.

You are advised to rectify the above-mentioned shortcomings under intimation to this department.

Yours Faithfully

(Atul Garg)
Director

Ph. 011-23414000

26/6/2025

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Sect., New Delhi- 110054.