



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/CGHS/2025/SZ/ 168

Dated: 07/04/2025

FIRE SAFETY CERTIFICATE

Certified that M/s **Delhi Apartments CGHS Ltd** located at Plot No-15 C, Sector-22, Dwarka, New Delhi-110077, having five high-rise blocks comprised of **Partial Basement, Ground/Stilt plus 08 upper floors**, was issued **NOC** by this department vide letter No. F6/DFS/MS/CGHS/09/524 Dated 20/02/2009. The residential premise was re-inspected by the officer concerned of this department on 26/03/2025 in the presence of Sh. Sanjeev Nath (President) & Smt. Sudha Sinha (Gen. Secretary) and found that said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and found that the said premises is fit for occupancy class "**Residential A-4**" (Apartment) with effect from 07/04/2025 for a period of **five years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/04/2025 at New Delhi by

(ATUL GARG)
DIRECTOR
Ph. 011-23414000

Copy to: -

1. President, M/s Delhi Apartments CGHS Ltd located at Plot No-15 C, Sector-22, Dwarka, New Delhi-110077
2. The Joint Director (L&I), Building Section, Delhi Development Authority, Vikash Sadan, INA, New Delhi-110023

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, months prior to its expiry.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

N-10

INSPECTION REPORT

1.	Name & address of the building	Delhi Apartments CGHS Ltd, Plot No. 15C, Sector-22, Dwarka, New Delhi-110077		
2.	Type of Occupancy	Residential Group 'A' (Apartment)		
3.	Building Comprised of	05 Blks - Partial Bt. + G/Stilt + 8 UFs.		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F6/DFS/MS/CGHS/09/524 Dt. 20/02/2009		
6.	Fire Safety directives Letter No.	F6/MS/DFS/CGHS/99/2561 Dt. 15/01/1991 F.6/DFS/MS/2003/2865/(CGHS) Dt. 21/11/2003 F.6/DFS/MS/BP/2017/212 dated 10/07/2017		
7.	Date of inspection	26/03/2025		
8.	Name of the Inspecting Officer	ADO (DWK)		
9.	Name and designation of Officer from the building side	Sh. Sanjeev Nath (President) Smt. Sudha Sinha (Gen. Secretary)		
10.	Year of Construction	1998		
11.	Applicant's letter No.	E-mail Dt. 08/03/25 thedelhiapartments@gmail.com		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	06 mtr	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02nos (each blk)	Provided	MR
	• Basements	2 + 2 Ramp	N/A	N/A
	b. Width of staircases			
	• Upper floors	1.25m & 1.0m	1.12m to 1.15m & 0.92m	MR (Old case)
	• Basements	1.25m & Ramp	1.12m to 1.15m & 0.92m + ramp	MR (Old case)
	c. Protection of exits			
	• Fire check door	Reqd. in Bt.	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	• Fire check door	Reqd. in Bt.	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			
	• Basement.	Required	Provided	MR
	• Upper floors	Required	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	02nos./Floor	Provided	MR
	• Types	CO ₂ & WCO ₂	Provided	MR
	• ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One (Each Blk)	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

80

7.	Automatic fire detection and alarming system.			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	One (Each Blk)	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	06 Nos	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM (Each Blk)	MR
	➤ Head of the pump	40 mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water storage for firefighting			
	• Underground tank capacity	2,00,000 ltr	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltr	10 Kl (Each Blk)	MR
		Required	Provided	MR
15.	Exit Signage			
16.	Provision of lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby Power Supply			
		Required	Provided	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

19.	Fire Control Room	N/A	N/A	N/A
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
20.	➤ Building Floor Plans	Required	CO ₂ fire extinguisher near electric panel	MR
	Special Fire Protection Systems for Protection of Special Risks, if any;			

The shortcomings issued vide this department letter No. F6/DFS/MS/CGHS/SZ/2024/402 dated 15/07/2024 found complied.

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/CGHS/09/524 dated 20/02/2009, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for perusal/approval and signature please.

[Signature]
 Signature of the Inspecting Officer
 Name: Santosh Kumar
 Designation: ADO (DWK)

~~DO (SW)~~

[Signature]
1/4/25

[Signature]

[Signature]
2/4/2025

~~Director~~
[Signature]
3/4/25

[Signature]

Sir, F.I. letter is put up for your sig. pl

~~Director~~
[Signature]

[Signature]
04.04.25