

ch20

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI- 110001

No. F6/DFS/MS/Educational/2025/SZ/ 410

Dated: 22/08/2025

To,
The Managing Trustee,
Delhi College of Nursing (unit of Shri Shyama Health Trust),
3-A, 4-A, 5 & 5-A(B), Ph.-1, Shyam Vihar, New Delhi-110043.

Sub: - Regarding issuance of "FSC" from fire safety point of view in r/o Delhi College of Nursing (unit of Shri Shyama Health Trust) at 3-A, 4-A, 5 & 5-A(B), Ph.-1, Shyam Vihar, New Delhi-110043.

Sir,

Please refer to your letter No. SSHT/HR/2025/252, dated 14.07.2025, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 05.08.2025 in the presence of Manager, to verify the fire safety arrangements in accordance with the rules. At the time of inspection, it was observed that the collage building is comprised of ground plus three upper floors, **and following shortcomings observed: -**

1. Two staircases having width of 1.0 m each found provided against requirements of two staircases with width of 1.50 m each.
2. First aid hose reel/hydrant found not provided.
3. Terrace fire pump of 450 LPM found not provided.
4. Overhead water storage tank of 10,000 ltrs. found not provided.
5. Exit signage's are found not provided.

In view of above, **fire safety certificate cannot be issued at this stage**. Therefore, you are **requested to rectify the above said shortcomings** under the intimation to this department for further necessary action in the matter, and running collage in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully


21/8/2025
(Virendra Singh)
Chief Fire Officer
9/9/16

Copy to:-

1. The Director, Delhi Nursing Council, A.B. College of Nursing Building, L.N. Hospital, New Delhi- 110002. : - **for necessary action please.**