



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6/DFS/MS/2024/WZ/ 15

Dated: 22/04/2025

FIRE SAFETY CERTIFICATE

Certified that the **Delhi Institute of Advanced Studies** located at **Plot No-6, Sec-25, Delhi-110085**, comprised of **Ground + 04 upper floors** owned/ occupied by **Delhi Institute of Advanced Studies** was issued fire safety certificate vide letter no. **F.6/DFS/MS/2022/WZ/29** dated **20.01.2022**. The premises was re-inspected by the officer concerned of Fire Service and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety accordance with rule 33 of the Delhi Fire Service rule 2010 and verified by the officer concerned of Delhi Fire Service on **04.04.2025** in the presence of **Sh. Prahalad Singh** and that the premises is fit for occupancy under **Institutional Building** with effect from 22/04/2025 for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules, 2010.

Issued on 22/04/2025 at New Delhi by

(Atul Garg)
DIRECTOR
Ph: 011-23414000

Copy to :-

1. The Director, Delhi Institute of Advanced Studies, Plot No-6, Sec-25, Delhi-110085.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building	Delhi Institute of Advanced Studies, Plot No-6, Sec-25, Delhi-110085.			
2. Type of Occupancy	Educational (Group-B)			
3. Type of Case	Renewal (Ground + 04 upper floors)			
4. Details of Previous NOC	F.6/DFS/MS/2022/WZ/29 dated 20.01.2022.			
5. Fire Safety directives letter No	F.6/DFS/MS/2004/1822 dated 18.08.2024.			
6. Date of inspection	04.04.2025			
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
8. Name and designation of officers From the building side	Mr. Prahalad Singh			
9. Year of Construction	2002			
10. Applicant's letter No.	OD No.14364 dated 12.03.2025.			

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	6m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	• Upper Floors	03nos.	03nos.	MR
	• Basements	-NA-	-NA-	-NA-
	e. Width of staircases			
	• Upper Floor	1.5m	Provided	MR
	• Basements	-NA-	-NA-	-NA-
	f. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	03nos.	Provided	MR
	e. Width of Corridor	Required	Provided	MR
	f. Door Size	-NA-	-NA-	-NA-
3.	Compartmentation			
	f) Fire check door	-NA-	-NA-	-NA-
	g) Sealing of electrical shafts	-NA-	-NA-	-NA-
	h) Fire Rating of shaft door	-NA-	-NA-	-NA-
	i) Water Curtain	-NA-	-NA-	-NA-
	j) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	c) Basements	31 /c per hour	Exhaust fan	MR
	d) Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	d) Total numbers	26nos.	Provided	MR
	e) Types	ABC/CO2	ABC/CO2	MR
	f) IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	d) Total numbers on each floor	02nos.	Provided	MR
	e) Length of hose reel hose	30mm	Provided	MR
	f) Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			

	f) Type of detectors	-NA-	-NA-	-NA-
	g) Location of Main Panel	-NA-	-NA-	-NA-
	h) Location of Repeater Panel	-NA-	-NA-	-NA-
	i) Alternate source of power	-NA-	-NA-	-NA-
	j) Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	d) Basement	-NA-	-NA-	-NA-
	e) Ground & Upper Floors	-NA-	-NA-	-NA-
	f) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	d) Size of riser/down-comer	-NA-	-NA-	-NA-
	e) Number of hydrants per floor	-NA-	-NA-	-NA-
	f) Hose Box	-NA-	-NA-	-NA-
12.	Yard Hydrants			
	c) Total number of hydrants	Required	Provided	MR
	d) Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	2850lpm	Provided	MR
	➤ Head of Main pump	40m	Provided	MR
	➤ Number of main pumps	01nos.	Provided	MR
	➤ Jockey Pump out put	750lpm	Provided	MR
	➤ Jockey pump head	40m	Provided	MR
	➤ Standby Pump out put	2850lpm	Provided	MR
	➤ Standby Pump Head	40m	Provided	MR
	➤ Auto Starting/Manual Stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	Terrace level			
	➤ Discharge of pump	900lpm	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	1,00,000ltr	1,00,000ltr	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	f) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	g) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	h) Communication In lift Car	Required	Provided	MR
	i) Fireman's Grounding Switch	Required	Provided	MR
	j) Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			

	c) Total Area	-NA-	-NA-	-NA-
	d) Location	-NA-	-NA-	-NA-
	Fire Control Room			
	f) Detector System Panel	-NA-	-NA-	-NA-
	g) Flow Switch Panel	-NA-	-NA-	-NA-
	h) PA System Panel	-NA-	-NA-	-NA-
	i) Battery backup	-NA-	-NA-	-NA-
	j) Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:			

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part-4, and removal of shortcomings issued vide letter no. 01 dated 06.01.2025, the FSC issued vide letter no. F.6/DFS/MS/2022/WZ/29 dated 20.01.2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

D.B Mukherjee
DO (NW)

DCFO/1083-NW
Dated 11/04/25

CFO / 15/4/2025
Director / 16/4/25
Director / 17/4/25

Fr letter is put
up for kind
perusal and
Signature please

17/4/25